


# Decentralised Ventilation Units







### **Model UZS ventilation unit for floor installation.**

### **Decentralised ventilation unit for floor installation, for heating, cooling and forced convection ventilation.**

#### **Description**

Decentralised units are suitable for a broad range of applications within the context of modern building services engineering. In new buildings, their compact and innovative designs allow them to be highly adaptable for integration into the facade structure. Meanwhile, the restricted spaces that accompany renovation tasks in old buildings often make them the only solution when it comes to room ventilation.

The UZS has been designed for use in false floors. Its compact design and useful option of integration into the floor area enables buildings to incorporate floor-to-ceiling glass facades. A direct external air connection via the facade also makes it possible to do away with complicated networks of air ducts. A 2-pipe or 4-pipe convective element ensures the temperature of the external air is controlled as necessary.

What is more, the low-noise addition of secondary air by means of an integrated secondary air fan unit means high thermal loads can be removed. Used in conjunction with a conventional floor convector (such as the emcotherm model KQKL), this model is able to increase the useful power supplied to the room several times over. The customisable, flexible control options enabled by the emcovent control units or an existing building management system make the emcovent UZS a particularly user-friendly and energy-efficient unit.

All components conform to VDI 6022.


#### **Application areas**

Decentralised floor ventilation units are ideally suited to areas with high demands in terms of room air quality and thermal comfort.

- Offices and administration rooms
- Business premises
- Reception areas and foyers
- Exhibition rooms
- Rooms requiring external air
- Rooms where windows cannot be opened
- Rooms whose appearance and layout should not be disturbed by heating components.

#### **Product benefits**

- Eurokonus valve connection for time-saving valve installation
- System for heating, cooling and ventilation
- High calorific output with low acoustic load
- Pleasant room climate thanks to air supply in the vicinity of the facade
- Load-bearing
- For use in false floors
- Can be adapted to suit the specific requirements of the building
- Infinitely adjustable control
- Low installation depth
- Energy-efficient EC fan




#### Method of operation

#### Outdoor air operation only:


The external air (ODA) is drawn in through an opening in the facade, by means of an EC radial fan that controls flow volume, and passes through a filter element (F7). The supply air opening is closed by a return spring motor when the unit is switched off (normally closed). The energy-saving, flow volume-controlling EC fan units compensate

for any pressure fluctuations at the facade. The air then reaches a sound absorption unit before flowing under a heat exchanger (available as a 2-pipe or 4-pipe system) and being heated or cooled. It can now be supplied to the room via the entire duct length in the vicinity of the facade.



#### Mixed air operation only:


This type of operation involves a combination of outdoor air (ODA) and secondary air operation (SEC). These two air volume flows are merged underneath the convector element. The mixture of room air and secondary air (SEC) increases the useful power of the unit several times over. The mixed air (MIA) is then adjusted to the required temperature by the convector element and supplied to the room in the vicinity of the facade.



#### Secondary air operation only:

In the case of secondary air operation, the room air is drawn in by a crossflow fan at the room side, passes through the heat exchanger, and is fed into the room in the vicinity of the facade.

## Ventilation unit for floor installation, model UZS – configuration and component description



No.	Dimension	Value	Unit
	<b>Size</b>	<b>345</b>	—
1	Duct length	1150	mm
2	Ribbed convector length	451	mm
3	Width (total)	603	mm
4	Width (visible area)	345	mm
5	Height (total)	200	mm
6	Height (underneath floor)	143	mm
7	Width of sound insulating duct	258	mm

Dimensions and position of the external air connection can be individually adapted.

### Available as an option:

#### Preinstalled water connection

Water connections preinstalled at the factory are available as accessories for emcotherm floor convectors. The connection set consists of:

1. Thermostat valve  
Standard TVU-E or TVU-D  
(optional: TVU-V-E or TVU-V-D)
2. Thermoelectric actuator, model TS, 230 V (optional, subject to an additional charge: model TS, 24 V)
3. Shutoff return screw connection
4. Connections inside tray, fully piped and leading outward (connection  $\frac{3}{4}$ " AG); testing for leaks


### Benefits:

- Huge time savings during installation
- Dirt cannot get into the floor tray during installation as the tray is able to remain sealed
- The media and electrical connections are supplied outside of the floor tray
- Media connections are fully tested for leaks at the factory

### Available as an option:

Ready-to-use electrical version

All electrical components are pre-wired at the factory and attached to the exterior of the tray by means of screw-in connectors. The customer can carry out wiring work outside the tray easily using the mating connectors supplied.



*Schema of inspection option*

### **UZS – inspection option**

During the development of the UZA, ease of installation and maintenance was placed high on the agenda. Filter units, actuators, damper registers and so on can be accessed with ease by removing the cover grid. If required, maintenance can also be performed on the supply air fan units by removing the function modules via the cover grid. What is more, it is not even necessary to disconnect the water-side connection, meaning that huge time savings can be made when draining the heating system too. The ability to remove all the unit components simply by taking off the cover grid saves the need for additional inspection openings in the floor area. As a result, the floor covering (carpet, tiles, etc.) can be coordinated directly with the floor unit itself. It is even possible to put down screed, assuming minimum installation height specifications are adhered to.

In most cases, units are integrated into the building structure during the preliminary building work, something which often results in them getting extremely dirty. However, the fixed piping system described previously allows piping to be installed quickly at the water side without the need to reach inside the tray or, therefore, remove the installation protection cover. As a result, not only is the installation process guaranteed to be quick, but it also prevents the units from getting dirty.

As a means of providing electrical components with full protection against damage caused by dirt during preliminary building work, function units containing electrical components can be supplied further down the line thanks to the modular unit structure. The empty housing with installation protection cover is installed and fastened in place during the preliminary building work. It is possible to connect the piping at the water side to the tray as early as this point. Additionally, the electrical cables required come fully pre-wired

and are attached to the exterior of the tray by means of screw-in connectors. The customer can carry out wiring work outside the tray easily using the mating connectors supplied. Once the preliminary building work is complete, the function units can then be simply inserted and connected up.

The images above illustrate how function units are removed from the UZA.

The first function unit can be removed from above once the cover grating has been removed and the damper register has been folded back. Following this, the second function unit can be pulled into the front empty tray area and then also removed from above.

## UZS (width 345 mm, length 1150 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, summer (cooling)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	6
Width	m	5.00	Return temperature			$t_r$	°C	12
Depth	m	4.00	Air inlet temperature, secondary air			$t_{sec}$	°C	26
Surface area	$m^2$	20	Relative humidity, secondary air			$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air			$t_{oda}$	°C	32
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air			$\varphi_{oda}$	%	40

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2-pipe and 4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	60	90	120
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	38	79	130	180	220	0	0	0	0
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	38	79	130	180	220	30	60	90	120
Sound power level		$L_{wa}$	dB(A)	27	30	38	48	56	29	29	35	42
125 Hz		$L_{wa125}$	dB	30	35	39	44	48	33	38	45	51
250 Hz		$L_{wa250}$	dB	20	29	37	43	48	35	33	38	45
500 Hz		$L_{wa500}$	dB	18	25	36	46	56	21	24	31	37
1000 Hz		$L_{wa1000}$	dB	21	24	33	43	49	13	19	28	35
2000 Hz		$L_{wa2000}$	dB	15	18	29	40	47	13	14	22	32
4000 Hz		$L_{wa4000}$	dB	18	22	27	33	41	18	16	17	23
8000 Hz		$L_{wa8000}$	dB	23	23	23	26	33	23	23	23	23
Sound pressure level <sup>2)</sup>		$L_p$	dB(A)	21	24	32	42	50	23	23	29	36
Power consumption		$p_{el}$	W	1	2	5	8	13	3	4	6	10
2-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	9	11	12	13	13	7	10	11	12
Condensate quantity		$\dot{m}_k$	l/h	0.2	0.3	0.4	0.5	0.6	0.2	0.4	0.6	0.7
Water mass flow rate		$\dot{m}_w$	l/h	50	89	131	165	188	59	102	141	177
Pressure loss, water side		$\Delta p_w$	kPa	0.0	0.6	1.4	2.3	2.9	0.2	0.9	1.7	2.6
Cooling power, sensitive		$\dot{Q}_{k,sens}$	W	216	400	608	793	927	250	443	625	796
Cooling power, latent		$\dot{Q}_{k,lat}$	W	134	223	307	362	388	163	271	365	445
<b>Cooling power, total</b>		$\dot{Q}_k$	<b>W</b>	<b>351</b>	<b>623</b>	<b>915</b>	<b>1155</b>	<b>1315</b>	<b>413</b>	<b>714</b>	<b>990</b>	<b>1241</b>
<b>Useful cooling power</b>		$\dot{Q}_{k,nutz}$	<b>W</b>	<b>212</b>	<b>391</b>	<b>595</b>	<b>775</b>	<b>907</b>	<b>182</b>	<b>309</b>	<b>425</b>	<b>531</b>
4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	9	11	12	13	14	8	10	12	12
Condensate quantity		$\dot{m}_k$	l/h	0.2	0.3	0.4	0.5	0.6	0.2	0.4	0.6	0.7
Water mass flow rate		$\dot{m}_w$	l/h	49	87	129	163	186	57	100	139	175
Pressure loss, water side		$\Delta p_w$	kPa	0.7	3.2	6.9	10.6	13.5	1.2	4.2	7.9	12.1
Cooling power, sensitive		$\dot{Q}_{k,sens}$	W	211	394	603	787	922	243	435	617	788
Cooling power, latent		$\dot{Q}_{k,lat}$	W	129	217	300	355	380	156	264	357	436
<b>Cooling power, total</b>		$\dot{Q}_k$	<b>W</b>	<b>340</b>	<b>611</b>	<b>903</b>	<b>1142</b>	<b>1302</b>	<b>399</b>	<b>699</b>	<b>974</b>	<b>1225</b>
<b>Useful cooling power</b>		$\dot{Q}_{k,nutz}$	<b>W</b>	<b>206</b>	<b>386</b>	<b>589</b>	<b>770</b>	<b>902</b>	<b>175</b>	<b>301</b>	<b>418</b>	<b>524</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																			
30	30	30	30	30	60	60	60	60	90	90	90	90	90	120	120	120	120	120	
20	62	115	170	218	10	52	105	160	208	10	31	93	147	199	5	16	68	134	188
50	92	145	200	248	70	112	165	220	268	100	121	183	237	289	125	136	188	254	308
31	33	39	48	56	31	33	39	48	56	36	36	40	48	56	42	42	43	49	56
35	37	40	45	48	38	40	41	45	48	45	46	46	48	50	51	51	51	52	53
35	36	39	44	48	33	35	39	44	48	38	39	41	44	48	45	45	47	49	
22	26	36	46	56	25	27	36	46	56	31	32	37	47	56	37	37	39	47	56
21	24	33	43	49	23	25	33	43	49	29	30	34	43	49	36	36	37	44	49
17	19	29	40	47	17	20	29	40	47	22	23	30	41	47	32	32	33	41	47
21	23	27	33	41	20	23	27	33	41	21	23	27	33	41	24	26	28	33	41
26	26	26	28	33	26	26	26	28	33	26	26	26	28	33	26	26	26	28	33
25	26	32	42	50	25	26	32	42	50	30	30	34	42	50	36	36	37	43	50
4	6	8	12	17	5	6	9	12	17	7	9	11	14	19	11	12	15	18	23
Mixed air operation. 2-pipe system																			
10	11	12	13	14	11	12	13	14	14	12	12	13	14	15	12	13	14	14	15
0.3	0.4	0.5	0.6	0.6	0.4	0.5	0.6	0.7	0.7	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.7
77	114	154	188	212	110	143	179	210	231	149	164	202	229	248	181	188	218	247	264
0.4	1.1	2.0	2.9	3.6	1.0	1.7	2.6	3.5	4.2	1.9	2.2	3.3	4.2	4.8	2.7	2.9	3.8	4.8	5.4
336	512	719	911	1063	483	650	844	1026	1168	663	741	958	1127	1273	814	852	1027	1225	1368
206	285	359	406	421	289	354	412	444	447	379	405	459	476	466	450	461	496	505	481
<b>541</b>	<b>797</b>	<b>1078</b>	<b>1317</b>	<b>1484</b>	<b>772</b>	<b>1003</b>	<b>1256</b>	<b>1469</b>	<b>1615</b>	<b>1041</b>	<b>1146</b>	<b>1417</b>	<b>1603</b>	<b>1739</b>	<b>1264</b>	<b>1313</b>	<b>1523</b>	<b>1730</b>	<b>1848</b>
<b>266</b>	<b>440</b>	<b>642</b>	<b>831</b>	<b>979</b>	<b>349</b>	<b>513</b>	<b>704</b>	<b>882</b>	<b>1022</b>	<b>463</b>	<b>540</b>	<b>754</b>	<b>920</b>	<b>1063</b>	<b>549</b>	<b>587</b>	<b>760</b>	<b>955</b>	<b>1096</b>
Mixed air operation. 4-pipe system																			
10	12	13	13	14	11	12	13	14	14	12	12	13	14	15	13	13	14	14	15
0.3	0.4	0.5	0.6	0.6	0.4	0.5	0.6	0.7	0.7	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.7
75	112	152	186	210	108	141	177	208	229	146	161	200	227	246	178	185	215	245	262
2.4	5.3	9.3	13.5	16.9	4.9	8.1	12.4	16.5	19.7	8.7	10.4	15.5	19.4	22.5	12.5	13.4	17.6	22.3	25.2
329	506	713	906	1057	476	643	838	1020	1162	655	734	951	1121	1266	806	845	1020	1218	1361
199	277	352	398	414	281	346	404	436	438	370	396	451	468	457	441	452	487	496	472
<b>528</b>	<b>784</b>	<b>1064</b>	<b>1304</b>	<b>1471</b>	<b>757</b>	<b>989</b>	<b>1242</b>	<b>1455</b>	<b>1601</b>	<b>1025</b>	<b>1130</b>	<b>1402</b>	<b>1588</b>	<b>1724</b>	<b>1248</b>	<b>1297</b>	<b>1507</b>	<b>1714</b>	<b>1833</b>
<b>260</b>	<b>434</b>	<b>636</b>	<b>825</b>	<b>973</b>	<b>342</b>	<b>506</b>	<b>697</b>	<b>876</b>	<b>1016</b>	<b>456</b>	<b>533</b>	<b>748</b>	<b>914</b>	<b>1057</b>	<b>542</b>	<b>580</b>	<b>753</b>	<b>949</b>	<b>1089</b>

## UZS (width 345 mm, length 1150 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, summer (cooling)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	10
Width	m	5.00	Return temperature			$t_r$	°C	15
Depth	m	4.00	Air inlet temperature, secondary air			$t_{sec}$	°C	26
Surface area	$m^2$	20	Relative humidity, secondary air			$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air			$t_{oda}$	°C	32
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air			$\varphi_{oda}$	%	40

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2-pipe and 4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	60	90	120
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	38	79	130	180	220	0	0	0	0
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	38	79	130	180	220	30	60	90	120
Sound power level		$L_{WA}$	dB(A)	27	30	38	48	56	29	29	35	42
125 Hz		$L_{WA125}$	dB	30	35	39	44	48	33	38	45	51
250 Hz		$L_{WA250}$	dB	20	29	37	43	48	35	33	38	45
500 Hz		$L_{WA500}$	dB	18	25	36	46	56	21	24	31	37
1000 Hz		$L_{WA1000}$	dB	21	24	33	43	49	13	19	28	35
2000 Hz		$L_{WA2000}$	dB	15	18	29	40	47	13	14	22	32
4000 Hz		$L_{WA4000}$	dB	18	22	27	33	41	18	16	17	23
8000 Hz		$L_{WA8000}$	dB	23	23	23	26	33	23	23	23	23
Sound pressure level <sup>2)</sup>		$L_p$	dB(A)	21	24	32	42	50	23	23	29	36
Power consumption		$p_{el}$	W	1	2	5	8	13	3	4	6	10
2-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	12	14	15	16	16	11	13	14	15
Condensate quantity		$\dot{m}_k$	l/h	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.4	0.5
Water mass flow rate		$\dot{m}_w$	l/h	44	75	107	131	146	58	98	134	166
Pressure loss, water side		$\Delta p_w$	kPa	0.0	0.4	0.9	1.4	1.8	0.1	0.8	1.5	2.3
Cooling power, sensitive		$\dot{Q}_{k,sens}$	W	172	318	484	630	737	212	376	530	675
Cooling power, latent		$\dot{Q}_{k,lat}$	W	83	119	139	133	112	126	197	253	296
Cooling power, total		$\dot{Q}_k$	W	255	437	622	763	849	339	573	783	971
Useful cooling power		$\dot{Q}_{k,nutz}$	W	168	311	473	616	721	146	244	334	416
4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	13	14	15	16	16	12	14	15	15
Condensate quantity		$\dot{m}_k$	l/h	0.1	0.2	0.2	0.2	0.1	0.2	0.3	0.4	0.5
Water mass flow rate		$\dot{m}_w$	l/h	42	73	105	129	144	56	96	132	164
Pressure loss, water side		$\Delta p_w$	kPa	0.4	2.2	4.6	6.9	8.4	1.1	3.9	7.1	10.7
Cooling power, sensitive		$\dot{Q}_{k,sens}$	W	168	314	479	626	733	206	369	524	669
Cooling power, latent		$\dot{Q}_{k,lat}$	W	77	113	132	127	105	119	189	244	287
Cooling power, total		$\dot{Q}_k$	W	245	426	611	753	838	325	558	768	956
Useful cooling power		$\dot{Q}_{k,nutz}$	W	164	307	469	612	717	139	238	328	410

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation, 2-pipe and 4-pipe system																			
30	30	30	30	30	60	60	60	60	90	90	90	90	90	120	120	120	120	120	
20	62	115	170	218	10	52	105	160	208	10	31	93	147	199	5	16	68	134	188
50	92	145	200	248	70	112	165	220	268	100	121	183	237	289	125	136	188	254	308
31	33	39	48	56	31	33	39	48	56	36	36	40	48	56	42	42	43	49	56
35	37	40	45	48	38	40	41	45	48	45	46	46	48	50	51	51	51	52	53
35	36	39	44	48	33	35	39	44	48	38	39	41	44	48	45	45	47	49	
22	26	36	46	56	25	27	36	46	56	31	32	37	47	56	37	37	39	47	56
21	24	33	43	49	23	25	33	43	49	29	30	34	43	49	36	36	37	44	49
17	19	29	40	47	17	20	29	40	47	22	23	30	41	47	32	32	33	41	47
21	23	27	33	41	20	23	27	33	41	21	23	27	33	41	24	26	28	33	41
26	26	26	28	33	26	26	26	28	33	26	26	26	28	33	26	26	28	33	
25	26	32	42	50	25	26	32	42	50	30	30	34	42	50	36	36	37	43	50
4	6	8	12	17	5	6	9	12	17	7	9	11	14	19	11	12	15	18	23
Mixed air operation, 2-pipe system																			
13	14	15	16	16	14	15	16	16	17	15	15	16	17	17	15	16	16	17	17
0.2	0.2	0.3	0.2	0.2	0.3	0.3	0.3	0.3	0.2	0.4	0.4	0.4	0.3	0.2	0.5	0.5	0.4	0.3	0.2
72	100	129	152	166	104	128	153	172	182	139	150	175	189	197	169	173	191	205	210
0.3	0.8	1.4	1.9	2.3	0.9	1.4	2.0	2.4	2.7	1.6	1.9	2.5	2.9	3.1	2.4	2.5	3.0	3.4	3.5
279	418	581	734	853	407	538	690	833	945	560	621	790	922	1036	689	719	855	1009	1119
141	165	173	153	113	200	210	202	168	115	253	251	228	180	111	294	290	260	189	104
<b>420</b>	<b>583</b>	<b>754</b>	<b>887</b>	<b>966</b>	<b>608</b>	<b>748</b>	<b>893</b>	<b>1001</b>	<b>1060</b>	<b>813</b>	<b>872</b>	<b>1018</b>	<b>1103</b>	<b>1146</b>	<b>983</b>	<b>1009</b>	<b>1114</b>	<b>1198</b>	<b>1222</b>
<b>212</b>	<b>349</b>	<b>508</b>	<b>657</b>	<b>774</b>	<b>276</b>	<b>404</b>	<b>555</b>	<b>695</b>	<b>804</b>	<b>364</b>	<b>424</b>	<b>592</b>	<b>722</b>	<b>833</b>	<b>429</b>	<b>459</b>	<b>594</b>	<b>746</b>	<b>854</b>
Mixed air operation, 4-pipe system																			
13	15	15	16	17	14	15	16	16	17	15	15	16	17	17	15	16	16	17	18
0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.2	0.2	0.4	0.4	0.3	0.3	0.2	0.5	0.5	0.4	0.3	0.2
70	98	127	150	164	102	126	151	169	180	137	147	172	187	194	166	170	189	203	207
2.0	4.1	6.7	9.1	10.7	4.4	6.6	9.2	11.4	12.7	7.7	8.8	11.7	13.6	14.6	11.0	11.5	13.9	15.8	16.4
273	413	577	729	848	401	532	685	828	940	553	615	785	917	1031	683	713	849	1003	1114
134	158	166	146	106	193	203	195	160	108	245	243	220	172	102	285	282	251	181	95
<b>407</b>	<b>571</b>	<b>742</b>	<b>875</b>	<b>954</b>	<b>594</b>	<b>735</b>	<b>880</b>	<b>989</b>	<b>1048</b>	<b>798</b>	<b>858</b>	<b>1005</b>	<b>1090</b>	<b>1133</b>	<b>968</b>	<b>995</b>	<b>1100</b>	<b>1184</b>	<b>1209</b>
<b>206</b>	<b>344</b>	<b>504</b>	<b>653</b>	<b>770</b>	<b>270</b>	<b>399</b>	<b>550</b>	<b>690</b>	<b>800</b>	<b>358</b>	<b>419</b>	<b>586</b>	<b>717</b>	<b>828</b>	<b>423</b>	<b>453</b>	<b>588</b>	<b>740</b>	<b>849</b>

## UZS (width 345 mm, length 1150 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, summer (cooling)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	<b>16</b>
Width	m	5.00	Return temperature			$t_r$	°C	<b>18</b>
Depth	m	4.00	Air inlet temperature, secondary air			$t_{sec}$	°C	26
Surface area	$m^2$	20	Relative humidity, secondary air			$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air			$t_{oda}$	°C	32
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air			$\varphi_{oda}$	%	40

<sup>1)</sup>Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2-pipe and 4-pipe system	Symbol	Unit	Secondary air operation					External air operation			
			0	0	0	0	0	30	60	90	120
External air component	$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	0	0	0	0
Secondary air component	$\dot{V}_{sec}$	$m^3/h$	38	79	130	180	220	0	0	0	0
Supply air quantity	$\dot{V}_{sup}$	$m^3/h$	38	79	130	180	220	30	60	90	120
Sound power level	$L_{wa}$	dB(A)	27	30	38	48	56	29	29	35	42
125 Hz	$L_{wa125}$	dB	30	35	39	44	48	33	38	45	51
250 Hz	$L_{wa250}$	dB	20	29	37	43	48	35	33	38	45
500 Hz	$L_{wa500}$	dB	18	25	36	46	56	21	24	31	37
1000 Hz	$L_{wa1000}$	dB	21	24	33	43	49	13	19	28	35
2000 Hz	$L_{wa2000}$	dB	15	18	29	40	47	13	14	22	32
4000 Hz	$L_{wa4000}$	dB	18	22	27	33	41	18	16	17	23
8000 Hz	$L_{wa8000}$	dB	23	23	23	26	33	23	23	23	23
Sound pressure level <sup>2)</sup>	$L_p$	dB(A)	21	24	32	42	50	23	23	29	36
Power consumption	$p_{el}$	W	1	2	5	8	13	3	4	6	10
2-pipe system	Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature	$t_{sup}$	°C	17	18	19	19	19	16	18	18	19
Condensate quantity	$\dot{m}_k$	l/h	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1
Water mass flow rate	$\dot{m}_w$	l/h	50	91	139	181	212	99	158	209	251
Pressure loss, water side	$\Delta p_w$	kPa	0.0	0.7	1.6	2.7	3.6	0.8	2.1	3.5	4.9
Cooling power, sensitive	$\dot{Q}_{k,sens}$	W	116	213	325	423	494	164	290	408	520
Cooling power, latent	$\dot{Q}_{k,lat}$	W	0	0	0	0	0	67	79	79	66
<b>Cooling power, total</b>	$\dot{Q}_k$	<b>W</b>	<b>116</b>	<b>213</b>	<b>325</b>	<b>423</b>	<b>494</b>	<b>230</b>	<b>369</b>	<b>487</b>	<b>586</b>
<b>Useful cooling power</b>	$\dot{Q}_{k,nutz}$	<b>W</b>	<b>113</b>	<b>209</b>	<b>317</b>	<b>413</b>	<b>483</b>	<b>99</b>	<b>162</b>	<b>218</b>	<b>267</b>
4-pipe system	Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature	$t_{sup}$	°C	17	18	19	19	19	16	18	19	19
Condensate quantity	$\dot{m}_k$	l/h	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1
Water mass flow rate	$\dot{m}_w$	l/h	48	90	138	180	210	94	153	203	246
Pressure loss, water side	$\Delta p_w$	kPa	0.7	3.5	7.8	12.7	16.9	3.7	9.4	15.9	22.4
Cooling power, sensitive	$\dot{Q}_{k,sens}$	W	113	211	322	420	491	159	285	403	515
Cooling power, latent	$\dot{Q}_{k,lat}$	W	0	0	0	0	0	60	72	71	58
<b>Cooling power, total</b>	$\dot{Q}_k$	<b>W</b>	<b>113</b>	<b>211</b>	<b>322</b>	<b>420</b>	<b>491</b>	<b>219</b>	<b>356</b>	<b>474</b>	<b>573</b>
<b>Useful cooling power</b>	$\dot{Q}_{k,nutz}$	<b>W</b>	<b>110</b>	<b>206</b>	<b>315</b>	<b>411</b>	<b>480</b>	<b>94</b>	<b>157</b>	<b>213</b>	<b>262</b>

<sup>2)</sup>Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																			
30	30	30	30	30	60	60	60	60	90	90	90	90	90	120	120	120	120	120	
20	62	115	170	218	10	52	105	160	208	10	31	93	147	199	5	16	68	134	188
50	92	145	200	248	70	112	165	220	268	100	121	183	237	289	125	136	188	254	308
31	33	39	48	56	31	33	39	48	56	36	36	40	48	56	42	42	43	49	56
35	37	40	45	48	38	40	41	45	48	45	46	46	48	50	51	51	51	52	53
35	36	39	44	48	33	35	39	44	48	38	39	41	44	48	45	45	47	49	
22	26	36	46	56	25	27	36	46	56	31	32	37	47	56	37	37	39	47	56
21	24	33	43	49	23	25	33	43	49	29	30	34	43	49	36	36	37	44	49
17	19	29	40	47	17	20	29	40	47	22	23	30	41	47	32	32	33	41	47
21	23	27	33	41	20	23	27	33	41	21	23	27	33	41	24	26	28	33	41
26	26	26	28	33	26	26	26	28	33	26	26	26	28	33	26	26	28	33	
25	26	32	42	50	25	26	32	42	50	30	30	34	42	50	36	36	37	43	50
4	6	8	12	17	5	6	9	12	17	7	9	11	14	19	11	12	15	18	23
Mixed air operation. 2-pipe system																			
17	18	19	19	20	18	19	19	20	20	19	19	20	20	20	19	19	20	20	21
0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0
105	126	173	216	250	159	166	209	250	281	208	206	243	280	311	250	247	266	309	339
0.9	1.3	2.5	3.7	4.9	2.1	2.3	3.5	4.9	6.0	3.5	3.4	4.6	6.0	7.3	4.9	4.8	5.5	7.2	8.5
206	295	403	504	583	310	387	488	582	655	427	466	567	653	726	529	548	621	721	791
39	0	0	0	0	62	0	0	0	0	59	16	0	0	0	54	29	0	0	0
<b>245</b>	<b>295</b>	<b>403</b>	<b>504</b>	<b>583</b>	<b>372</b>	<b>387</b>	<b>488</b>	<b>582</b>	<b>655</b>	<b>486</b>	<b>482</b>	<b>567</b>	<b>653</b>	<b>726</b>	<b>583</b>	<b>577</b>	<b>621</b>	<b>721</b>	<b>791</b>
<b>141</b>	<b>228</b>	<b>335</b>	<b>434</b>	<b>511</b>	<b>182</b>	<b>259</b>	<b>358</b>	<b>451</b>	<b>522</b>	<b>236</b>	<b>275</b>	<b>375</b>	<b>460</b>	<b>532</b>	<b>276</b>	<b>295</b>	<b>368</b>	<b>467</b>	<b>536</b>
Mixed air operation. 4-pipe system																			
18	18	19	19	20	18	19	19	20	20	19	19	20	20	20	19	19	20	20	21
0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0
100	125	171	215	248	154	164	208	248	279	203	201	241	278	310	244	242	265	307	338
4.3	6.5	11.6	17.5	22.9	9.6	10.8	16.5	22.9	28.4	15.8	15.6	21.7	28.2	34.3	22.2	21.8	25.7	33.9	40.3
202	291	400	501	580	305	383	485	579	652	422	461	563	649	722	524	543	617	717	788
32	0	0	0	0	55	0	0	0	0	51	8	0	0	0	46	21	0	0	0
<b>234</b>	<b>291</b>	<b>400</b>	<b>501</b>	<b>580</b>	<b>360</b>	<b>383</b>	<b>485</b>	<b>579</b>	<b>652</b>	<b>473</b>	<b>470</b>	<b>563</b>	<b>649</b>	<b>722</b>	<b>570</b>	<b>564</b>	<b>617</b>	<b>717</b>	<b>788</b>
<b>137</b>	<b>225</b>	<b>331</b>	<b>431</b>	<b>508</b>	<b>177</b>	<b>255</b>	<b>355</b>	<b>447</b>	<b>519</b>	<b>232</b>	<b>271</b>	<b>371</b>	<b>456</b>	<b>529</b>	<b>271</b>	<b>290</b>	<b>364</b>	<b>463</b>	<b>533</b>

## UZS (width 345 mm, length 1150 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data winter (heating)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	75
Width	m	5.00	Return temperature			$t_r$	°C	65
Depth	m	4.00	Air inlet temperature, secondary air			$t_{sec}$	°C	20
Surface area	$m^2$	20	Relative humidity, secondary air			$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air			$t_{oda}$	°C	-12
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air			$\varphi_{oda}$	%	50

<sup>1)</sup>Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2-pipe and 4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	60	90	120
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	38	79	130	180	220	0	0	0	0
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	38	79	130	180	220	30	60	90	120
Sound power level		$L_{wa}$	dB(A)	27	30	38	48	56	29	29	35	42
Sound pressure level <sup>2)</sup>		$L_{pa}$	dB(A)	21	24	32	42	50	23	23	29	36
Power consumption		$p_{el}$	W	1	2	5	8	13	3	4	6	10
2-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	59.5	58.6	57.5	56.3	55.4	52.8	51.9	50.9	49.8
Water mass flow rate		$\dot{m}_w$	l/h	43	88	140	188	224	56	110	163	214
Pressure loss, water side		$\Delta p_w$	kPa	0.1	0.4	1.0	1.8	2.4	0.2	0.7	1.4	2.2
<b>Heating power, total</b>		$\dot{Q}_h$	<b>W</b>	<b>503</b>	<b>1024</b>	<b>1636</b>	<b>2196</b>	<b>2615</b>	<b>653</b>	<b>1288</b>	<b>1901</b>	<b>2491</b>
<b>Useful heating power</b>		$\dot{Q}_{h, nutz}$	<b>W</b>	<b>503</b>	<b>1024</b>	<b>1636</b>	<b>2196</b>	<b>2615</b>	<b>372</b>	<b>724</b>	<b>1051</b>	<b>1353</b>
4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	54.8	46.5	42.9	40.8	39.4	51.8	35.8	30.1	26.9
Water mass flow rate		$\dot{m}_w$	l/h	38	60	86	108	123	55	83	109	134
Pressure loss, water side		$\Delta p_w$	kPa	0.3	0.8	1.5	2.3	2.9	0.7	1.4	2.4	3.4
<b>Heating power, total</b>		$\dot{Q}_h$	<b>W</b>	<b>444</b>	<b>703</b>	<b>1001</b>	<b>1258</b>	<b>1432</b>	<b>643</b>	<b>963</b>	<b>1273</b>	<b>1568</b>
<b>Useful heating power</b>		$\dot{Q}_{h, nutz}$	<b>W</b>	<b>444</b>	<b>703</b>	<b>1001</b>	<b>1258</b>	<b>1432</b>	<b>361</b>	<b>359</b>	<b>345</b>	<b>314</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																			
30	30	30	30	30	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
20	62	115	170	218	10	52	105	160	208	10	31	93	147	199	5	16	68	134	188
50	92	145	200	248	70	112	165	220	268	100	121	183	237	289	125	136	188	254	308
31	33	39	48	56	31	33	39	48	56	36	36	40	48	56	42	42	43	49	56
25	26	32	42	50	25	26	32	42	50	30	30	34	42	50	36	36	37	43	50
4	6	8	12	17	5	6	9	12	17	7	9	11	14	19	11	12	15	18	23
Mixed air operation. 2-pipe system																			
54.9	55.7	55.3	54.4	53.5	52.5	53.5	53.4	52.7	51.8	51.2	51.7	51.7	51.1	50.3	49.9	50.1	50.3	49.7	48.9
79	124	177	228	269	122	166	218	267	306	174	195	255	301	342	219	230	279	334	375
0.4	0.8	1.6	2.5	3.4	0.8	1.4	2.3	3.3	4.3	1.5	1.9	3.0	4.1	5.2	2.3	2.5	3.6	5.0	6.2
922	1450	2070	2664	3141	1419	1939	2541	3112	3568	2026	2280	2972	3513	3986	2551	2681	3254	3901	4370
659	1241	1934	2599	3135	861	1419	2081	2716	3224	1181	1448	2194	2788	3311	1414	1548	2153	2852	3365
Mixed air operation. 4-pipe system																			
43.6	39.9	38.3	37.0	35.8	35.3	34.7	34.4	33.8	32.9	30.3	30.7	31.2	31.0	30.2	27.1	27.4	28.4	28.4	27.8
63	82	107	128	144	87	106	128	147	160	113	123	147	164	175	136	141	160	179	187
0.9	1.4	2.3	3.2	3.9	1.6	2.2	3.1	4.0	4.7	2.5	2.9	4.0	4.9	5.5	3.5	3.7	4.7	5.7	6.2
732	961	1244	1497	1674	1014	1232	1492	1717	1864	1324	1429	1713	1908	2036	1592	1644	1870	2084	2184
445	691	1003	1286	1484	404	623	900	1145	1306	390	490	777	981	1116	335	381	595	807	904

## UZS (width 345 mm, length 1150 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data winter (heating)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	75
Width	m	5.00	Return temperature			$t_r$	°C	65
Depth	m	4.00	Air inlet temperature, secondary air			$t_{sec}$	°C	20
Surface area	$m^2$	20	Relative humidity, secondary air			$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air			$t_{oda}$	°C	-12
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air			$\varphi_{oda}$	%	50

<sup>1)</sup>Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2-pipe and 4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	60	90	120
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	38	79	130	180	220	0	0	0	0
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	38	79	130	180	220	30	60	90	120
Sound power level		$L_{wa}$	dB(A)	27	30	38	48	56	29	29	35	42
Sound pressure level <sup>2)</sup>		$L_{pa}$	dB(A)	21	24	32	42	50	23	23	29	36
Power consumption		$p_{el}$	W	1	2	5	8	13	3	4	6	10
2-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	55.5	54.8	53.7	52.7	51.9	49.3	48.5	47.5	46.6
Water mass flow rate		$\dot{m}_w$	l/h	39	79	126	169	202	51	101	149	195
Pressure loss, water side		$\Delta p_w$	kPa	0.1	0.4	0.8	1.4	2.0	0.1	0.6	1.1	1.9
Heating power, total		$\dot{Q}_h$	W	453	922	1473	1976	2353	597	1178	1739	2278
Useful heating power		$\dot{Q}_{h, nutz}$	W	453	922	1473	1976	2353	330	641	930	1195
4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	51.3	43.8	40.6	38.7	37.4	48.4	33.7	28.5	25.5
Water mass flow rate		$\dot{m}_w$	l/h	34	54	77	97	110	50	75	100	123
Pressure loss, water side		$\Delta p_w$	kPa	0.2	0.6	1.3	1.9	2.4	0.5	1.2	2.0	2.9
Heating power, total		$\dot{Q}_h$	W	399	632	899	1128	1283	588	881	1163	1431
Useful heating power		$\dot{Q}_{h, nutz}$	W	399	632	899	1128	1283	319	309	286	248

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																			
30	30	30	30	30	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
20	62	115	170	218	10	52	105	160	208	10	31	93	147	199	5	16	68	134	188
50	92	145	200	248	70	112	165	220	268	100	121	183	237	289	125	136	188	254	308
31	33	39	48	56	31	33	39	48	56	36	36	40	48	56	42	42	43	49	56
25	26	32	42	50	25	26	32	42	50	30	30	34	42	50	36	36	37	43	50
4	6	8	12	17	5	6	9	12	17	7	9	11	14	19	11	12	15	18	23
Mixed air operation. 2-pipe system																			
51.2	52.1	51.7	50.9	50.1	49.1	50.0	49.9	49.3	48.6	47.9	48.3	48.4	47.9	47.2	46.7	46.8	47.1	46.6	45.9
72	113	160	206	243	111	151	197	241	276	159	178	231	273	309	200	210	254	304	340
0.3	0.7	1.3	2.1	2.8	0.7	1.2	1.9	2.8	3.5	1.3	1.6	2.6	3.5	4.3	2.0	2.1	3.0	4.2	5.2
839	1314	1872	2405	2834	1296	1763	2303	2816	3225	1851	2079	2700	3185	3609	2332	2449	2962	3542	3962
586	1106	1724	2317	2795	763	1261	1851	2417	2870	1045	1283	1948	2478	2942	1250	1369	1907	2530	2986
Mixed air operation. 4-pipe system																			
40.9	37.7	36.3	35.1	34.1	33.3	32.9	32.7	32.1	31.4	28.7	29.1	29.7	29.5	28.9	25.7	26.0	27.0	27.1	26.6
57	75	96	115	129	79	96	116	133	144	103	111	133	148	157	124	128	145	161	169
0.7	1.2	1.9	2.6	3.2	1.3	1.9	2.6	3.3	3.9	2.1	2.4	3.4	4.1	4.5	3.0	3.2	3.9	4.8	5.2
666	870	1121	1347	1504	925	1118	1348	1547	1677	1207	1301	1551	1722	1834	1452	1498	1697	1884	1970
392	609	885	1135	1309	348	541	784	1000	1141	326	413	665	844	960	267	308	494	678	761

## UZS (width 345 mm, length 1150 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data winter (heating)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	75
Width	m	5.00	Return temperature			$t_r$	°C	65
Depth	m	4.00	Air inlet temperature, secondary air			$t_{sec}$	°C	20
Surface area	$m^2$	20	Relative humidity, secondary air			$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air			$t_{oda}$	°C	-12
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air			$\varphi_{oda}$	%	50

<sup>1)</sup>Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2-pipe and 4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	60	90	120
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	38	79	130	180	220	0	0	0	0
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	38	79	130	180	220	30	60	90	120
Sound power level		$L_{wa}$	dB(A)	27	30	38	48	56	29	29	35	42
Sound pressure level <sup>2)</sup>		$L_{pa}$	dB(A)	21	24	32	42	50	23	23	29	36
Power consumption		$p_{el}$	W	1	2	5	8	13	3	4	6	10
2-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	51.6	50.9	50.0	49.1	48.3	44.9	44.2	43.3	42.3
Water mass flow rate		$\dot{m}_w$	l/h	35	70	112	151	179	49	97	143	187
Pressure loss, water side		$\Delta p_w$	kPa	0.0	0.3	0.7	1.2	1.6	0.1	0.5	1.1	1.7
Heating power, total		$\dot{Q}_h$	W	403	820	1309	1756	2091	573	1131	1669	2187
Useful heating power		$\dot{Q}_{h, nutz}$	W	403	820	1309	1756	2091	283	548	791	1011
4-pipe system		Symbol	Unit	Secondary air operation					External air operation			
Supply air temperature		$t_{sup}$	°C	47.8	41.2	38.3	36.5	35.4	44.0	30.0	24.9	22.1
Water mass flow rate		$\dot{m}_w$	l/h	30	48	68	86	97	48	72	96	118
Pressure loss, water side		$\Delta p_w$	kPa	0.2	0.5	1.0	1.5	1.9	0.5	1.1	1.9	2.7
Heating power, total		$\dot{Q}_h$	W	355	561	796	998	1135	564	845	1115	1372
Useful heating power		$\dot{Q}_{h, nutz}$	W	355	561	796	998	1135	272	226	167	94

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																			
30	30	30	30	30	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
20	62	115	170	218	10	52	105	160	208	10	31	93	147	199	5	16	68	134	188
50	92	145	200	248	70	112	165	220	268	100	121	183	237	289	125	136	188	254	308
31	33	39	48	56	31	33	39	48	56	36	36	40	48	56	42	42	43	49	56
25	26	32	42	50	25	26	32	42	50	30	30	34	42	50	36	36	37	43	50
4	6	8	12	17	5	6	9	12	17	7	9	11	14	19	11	12	15	18	23
Mixed air operation. 2-pipe system																			
47.0	48.1	47.9	47.2	46.5	44.8	45.9	46.0	45.6	45.0	43.6	44.1	44.5	44.1	43.5	42.4	42.7	43.1	42.8	42.2
68	104	146	187	220	106	142	183	222	253	152	169	216	253	285	192	201	240	284	315
0.3	0.6	1.1	1.7	2.3	0.6	1.0	1.7	2.4	3.0	1.2	1.4	2.3	3.0	3.7	1.8	2.0	2.7	3.7	4.5
791	1214	1709	2181	2561	1237	1654	2134	2588	2949	1770	1974	2525	2955	3327	2236	2340	2797	3308	3677
511	975	1527	2056	2482	656	1098	1623	2125	2527	893	1103	1691	2159	2569	1059	1164	1638	2185	2585
Mixed air operation. 4-pipe system																			
37.3	34.7	33.7	32.8	32.0	29.7	29.8	30.0	29.7	29.1	25.3	25.9	26.9	27.0	26.6	22.3	22.7	24.1	24.5	24.3
54	69	87	104	116	76	90	107	121	131	99	106	124	136	144	119	123	137	150	156
0.6	1.0	1.6	2.2	2.6	1.2	1.7	2.3	2.9	3.3	2.0	2.2	3.0	3.5	3.9	2.8	2.9	3.5	4.2	4.5
627	802	1021	1217	1352	882	1048	1246	1417	1527	1154	1233	1448	1592	1684	1391	1430	1599	1754	1821
327	512	752	970	1121	256	415	623	807	926	198	269	478	626	720	108	140	289	435	496



### **Model UZA ventilation unit for floor installation.**

**Decentralised ventilation unit for floor installation, for heating, cooling and forced convection ventilation with heat recovery.**

#### **Description**

The UZA is a ventilation unit for floor installation that offers the following functions:

- Supply air (SUP)
- Exhaust air (ETA)
- Heat recovery
- Heating
- Cooling

ventilation units for floor installation of this type have been designed to carry out ventilation and temperature control in rooms whilst adhering to comfort criteria.

The highly compact design of the emcovent UZA allows it to be integrated into the building structure with ease. A grid width of 345 mm in the visible area makes the unit the ideal choice even in buildings with high architectural demands.

All maintenance and inspection work can be carried out via the cover grid. This grid also makes it easy to remove function units.

Special insulation material conforming to VDI 6022 creates optimum thermal and sound insulation.

The heat recovery unit (WRG) reduces the amount of additional energy required for room temperature control to the absolute minimum.

If you are working with the heat recovery unit and there is a large difference in temperature between the external air and the air in the room, a stainless steel condensate trough is used to catch any condensate.

If required, this can then be discharged via a condensate drain. All components conform to VDI 6022. An integrated heat exchanger, available as a 2-pipe or 4-pipe system, conditions the room air and supplies air to the room whilst taking acoustic and comfort requirements into consideration.

The air volume flow of up to 120 m<sup>3</sup>/h (supply and exhaust air) is achieved by means of two EC radial fans that are linked from a control perspective. The unit can be controlled using either external emcovent control components or the building management system.

For the visible area of the unit, a linear grid or roll-up grid cover is available to choose from.



#### Application areas

Decentralised floor ventilation units are ideally suited to areas with high demands in terms of room air quality and thermal comfort.

- Offices and administration rooms
- Business premises
- Reception areas and foyers
- Exhibition rooms
- Rooms requiring external air
- Rooms where windows cannot be opened
- Rooms whose appearance and layout should not be disturbed by heating components

#### Product benefits

- Eurokonus valve connection for time-saving valve installation
- System for heating, cooling and ventilation
- High calorific output with low acoustic load
- Pleasant room climate thanks to air supply in the vicinity of the facade
- Load-bearing
- For use in false floors
- Can be adapted to suit the specific requirements of the building
- Infinitely adjustable control
- Low installation depth
- No additional inspection opening required thanks to modular structure

#### UZA – Method of operation

The outdoor air (ODA) is drawn in directly via the facade and passes through a filter element (F7).


The supply air opening is closed automatically by a return spring motor when the unit is switched off (normally closed). The flow volume-controlling EC fans compensate for any pressure fluctuations at the facade. There is a heat recovery unit located downstream of the supply air fan unit, which is responsible for energy ex-change between the supply air (SUP) and exhaust air (ETA) (heat recovery ratio of up to 60%).

Air whose temperature is precontrolled using this equipment is heated or cooled by a heat exchanger, according to the room temperature that is required. The conditioned supply air (SUP) is supplied to the room via the cover grating located in the visible area of the unit.

The exhaust air (ETA) is removed from the room via the cover and purified by a coarse dust filter (optional). Once the exhaust air has passed through the heat recovery unit, it is conveyed outdoors (EHA) via an exhaust air opening with flap.

The exhaust air flap performs the same functions as the supply air flap.

## UZA – Dimensions



Nr.	Size	Value	Unit
1	Length of empty housing (visible area)	1250	mm
2	Length of empty housing (underneath floor)	1074	mm
3	Width of housing (visible area)	345	mm
4	Width (total)	600	mm
5	Height of housing (total)	230	mm
6	Height of empty housing (underneath floor)	172	mm
7	Distance from air outlet to upper edge	86	mm
8	Height of air inlets	97	mm
9	Distance from air inlets to side	152	mm
10	Width of air inlets	298	mm
11	Distance between air inlets	348	mm

Dimensions and position of the supply and external air connections can be individually adapted.

#### Available as an option:

##### **preinstalled fixed connection**

Water connections preinstalled at the factory are available as accessories for emcotherm floor convectors.

The connection set consists of:

1. Thermostat valve  
Standard TVU-E or TVU-D  
(optional: TVU-V-E or TVU-V-D)
2. Continuous actuator emcoMFC-Z-MS-S
3. Shutoff return screw connection
4. Connections inside tray, fully piped and leading outward (connection  $\frac{3}{4}$ " AG); testing for leaks


#### Benefits:

- Huge time savings during installation
- Dirt cannot get into the floor tray during installation as the tray is able to remain sealed
- The media and electrical connections are supplied outside of the floor tray
- Media connections are fully tested for leaks at the factory

#### Available as an option:

ready-to-use electrical version.

All electrical components are prewired at the factory and attached to the exterior of the tray by means of screw-in connectors. The customer can carry out wiring work outside the tray easily using the mating connectors supplied.



*Schema of inspection option*

**UZA – inspection option** During the development of the emcovent UZA, ease of installation and maintenance was placed high on the agenda. Filter units, actuators, damper registers and so on can be accessed with ease by removing the cover grid. If required, maintenance can also be performed on the supply and exhaust air fan units, as well as the heat recovery unit, by removing the function modules via the cover grid. What is more, it is not even necessary to disconnect the water-side connection, meaning that huge time savings can be made when draining the heating system too. The ability to remove all the unit components simply by taking off the cover saves the need for additional inspection openings in the floor area. As a result, the floor covering (carpet, tiles, etc.) can be coordinated directly with the floor unit itself. It is even possible to put down screed, assuming minimum installation height specifications are adhered to.

In most cases, units are integrated into the building structure during the preliminary building work, something which often results in them getting extremely dirty. However, the fixed piping system described previously allows piping to be installed quickly at the water side without the need to reach inside the tray or, therefore, remove the installation protection cover. As a result, not only is the installation process guaranteed to be quick, but it also prevents the units from getting dirty.

As a means of providing electrical components with full protection against damage caused by dirt during preliminary building work, function units containing electrical components can be supplied further down the line thanks to the modular unit structure. The empty housing with installation protection cover is installed and fastened in place during the preliminary building work. It is possible to connect the piping at the water side to the tray as early as this point. Additionally, the electrical

cables required come fully pre-wired and are attached to the exterior of the tray by means of screw-in connectors. The customer can carry out wiring work outside the tray easily using the mating connectors supplied. Once the preliminary building work is complete, the function units can then be simply inserted and connected up.

The images above illustrate how function units are removed from the UZA.

The first function unit can be removed from above once the cover grating has been removed and the damper register has been folded back. Following this, the second function unit can be pulled into the front empty tray area and then also removed from above.

### UZA (length 1250 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, summer (cooling)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	6
Width	m	5.00	Return temperature			$t_r$	°C	12
Depth	m	4.00	Relative humidity, room			$t_{IDA}$	°C	26
Surface area	$m^2$	20	Air inlet temperature, external air			$t_{ODA}$	°C	32
Volume	$m^3$	60	Relative humidity, external air			$\varphi_{ODA}$	%	40
Distance from sound source <sup>1)</sup>	m	3.00						

<sup>1)</sup>Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	External air operation			
Air volume flow		$\dot{V}$	$m^3/h$	30	60	90	120
Sound power level		$L_{WA}$	dB(A)	27	30	38	45
125 Hz		$L_{W125}$	dB	33	36	43	50
250 Hz		$L_{W250}$	dB	24	32	40	47
500 Hz		$L_{W500}$	dB	22	30	37	40
1000 Hz		$L_{W1000}$	dB	14	23	31	38
2000 Hz		$L_{W2000}$	dB	8	18	27	35
4000 Hz		$L_{W4000}$	dB	20	13	17	25
8000 Hz		$L_{W8000}$	dB	23	15	14	17
Sound pressure level <sup>2)</sup>		$L_{PA}$	dB(A)	20	24	32	39
Power consumption		$p_{el}$	W	5	11	18	26
2-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	4.5	9.5	10.0	10.6
Condensate quantity		$\dot{m}_k$	l/h	0.2	0.3	0.5	0.6
Water mass flow rate		$\dot{m}_w$	kg/h	58	88	131	169
Pressure loss, water side		$\Delta p_w$	kPa	2.2	4.9	10.2	16.4
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	38	67	90	112
Cooling power, sensitive		$\dot{Q}_{K,sens}$	W	239	386	574	748
Cooling power, latent		$\dot{Q}_{K,lat}$	W	165	231	340	432
<b>Cooling power, total</b>		$\dot{Q}_k$	<b>W</b>	<b>441</b>	<b>684</b>	<b>1004</b>	<b>1291</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>216</b>	<b>332</b>	<b>483</b>	<b>619</b>
4-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	8.1	12.4	12.8	13.4
Condensate quantity		$\dot{m}_k$	l/h	0.2	0.2	0.3	0.4
Water mass flow rate		$\dot{m}_w$	kg/h	47	69	102	131
Pressure loss, water side		$\Delta p_w$	kPa	1.1	2.2	4.6	7.3
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	38	67	90	112
Cooling power, sensitive		$\dot{Q}_{K,sens}$	W	203	328	488	636
Cooling power, latent		$\dot{Q}_{K,lat}$	W	128	156	227	281
<b>Cooling power, total</b>		$\dot{Q}_k$	<b>W</b>	<b>368</b>	<b>551</b>	<b>805</b>	<b>1028</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>181</b>	<b>274</b>	<b>397</b>	<b>507</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

### UZA (length 1250 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, summer (cooling)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	<b>10</b>
Width	m	5.00	Return temperature			$t_r$	°C	<b>15</b>
Depth	m	4.00	Relative humidity, room			$t_{IDA}$	°C	26
Surface area	$m^2$	20	Air inlet temperature, external air			$t_{ODA}$	°C	32
Volume	$m^3$	60	Relative humidity, external air			$\varphi_{ODA}$	%	40
Distance from sound source <sup>1)</sup>	m	3.00	<sup>1)</sup> Direction factor Q=4 (sphere quadrant)					

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	External air operation			
Air volume flow		$\dot{V}$	$m^3/h$	30	60	90	120
Sound power level		$L_{WA}$	dB(A)	27	30	38	45
125 Hz		$L_{W125}$	dB	33	36	43	50
250 Hz		$L_{W250}$	dB	24	32	40	47
500 Hz		$L_{W500}$	dB	22	30	37	40
1000 Hz		$L_{W1000}$	dB	14	23	31	38
2000 Hz		$L_{W2000}$	dB	8	18	27	35
4000 Hz		$L_{W4000}$	dB	20	13	17	25
8000 Hz		$L_{W8000}$	dB	23	15	14	17
Sound pressure level <sup>2)</sup>		$L_{PA}$	dB(A)	20	24	32	39
Power consumption		$p_{el}$	W	5	11	18	26
2-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	8	12.6	13.3	13.8
Condensate quantity		$\dot{m}_k$	l/h	0.2	0.2	0.3	0.4
Water mass flow rate		$\dot{m}_w$	kg/h	57	81	117	151
Pressure loss. water side		$\Delta p_w$	kPa	2.2	4.1	8.3	13.1
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	38	67	90	112
Cooling power. sensitive		$\dot{Q}_{K,sens}$	W	203	323	476	621
Cooling power. latent		$\dot{Q}_{K,lat}$	W	128	149	209	259
<b>Cooling power. total</b>		$\dot{Q}_k$	<b>W</b>	<b>369</b>	<b>538</b>	<b>775</b>	<b>992</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>181</b>	<b>269</b>	<b>385</b>	<b>492</b>
4-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	11.1	15	15.6	16.1
Condensate quantity		$\dot{m}_k$	l/h	0.1	0.1	0.1	0.2
Water mass flow rate		$\dot{m}_w$	kg/h	45	60	86	110
Pressure loss. water side		$\Delta p_w$	kPa	1	1.7	3.3	5.2
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	38	67	90	112
Cooling power. sensitive		$\dot{Q}_{K,sens}$	W	173	275	404	528
Cooling power. latent		$\dot{Q}_{K,lat}$	W	90	75	99	112
<b>Cooling power. total</b>		$\dot{Q}_k$	<b>W</b>	<b>301</b>	<b>416</b>	<b>593</b>	<b>752</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>150</b>	<b>221</b>	<b>314</b>	<b>398</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

### UZA (length 1250 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, summer (cooling)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	<b>16</b>
Width	m	5.00	Return temperature			$t_r$	°C	<b>18</b>
Depth	m	4.00	Room air temperature			$t_{IDA}$	°C	26
Surface area	$m^2$	20	Air inlet temperature, external air			$t_{ODA}$	°C	32
Volume	$m^3$	60	Relative humidity, external air			$\varphi_{ODA}$	%	40
Distance from sound source <sup>1)</sup>	m	3.00	<sup>1)</sup> Direction factor Q=4 (sphere quadrant)					

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	External air operation			
Air volume flow		$\dot{V}$	$m^3/h$	30	60	90	120
Sound power level		$L_{WA}$	dB(A)	27	30	38	45
125 Hz		$L_{W125}$	dB	33	36	43	50
250 Hz		$L_{W250}$	dB	24	32	40	47
500 Hz		$L_{W500}$	dB	22	30	37	40
1000 Hz		$L_{W1000}$	dB	14	23	31	38
2000 Hz		$L_{W2000}$	dB	8	18	27	35
4000 Hz		$L_{W4000}$	dB	20	13	17	25
8000 Hz		$L_{W8000}$	dB	23	15	14	17
Sound pressure level <sup>2)</sup>		$L_{PA}$	dB(A)	20	24	32	39
Power consumption		$p_{el}$	W	5	11	18	26
2-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	12.8	16.8	17.5	18.0
Condensate quantity		$\dot{m}_k$	l/h	0.1	0	0	0
Water mass flow rate		$\dot{m}_w$	l/h	95	110	150	194
Pressure loss. water side		$\Delta p_w$	kPa	5.5	7.1	12.7	20.6
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	38	67	90	112
Cooling power. sensitive		$\dot{Q}_{K,sens}$	W	156	240	348	453
Cooling power. latent		$\dot{Q}_{K,lat}$	W	66	16	1	0
<b>Cooling power. total</b>		$\dot{Q}_k$	<b>W</b>	<b>260</b>	<b>322</b>	<b>439</b>	<b>564</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>133</b>	<b>186</b>	<b>257</b>	<b>323</b>
4-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	15.1	18.6	19.3	19.7
Condensate quantity		$\dot{m}_k$	l/h	0	0	0	0
Water mass flow rate		$\dot{m}_w$	l/h	69	87	126	165
Pressure loss. water side		$\Delta p_w$	kPa	2.2	3.3	6.6	10.9
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	38	67	90	112
Cooling power. sensitive		$\dot{Q}_{K,sens}$	W	132	203	294	385
Cooling power. latent		$\dot{Q}_{K,lat}$	W	29	0	0	0
<b>Cooling power. total</b>		$\dot{Q}_k$	<b>W</b>	<b>199</b>	<b>270</b>	<b>384</b>	<b>496</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>110</b>	<b>149</b>	<b>204</b>	<b>255</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

### UZA (length 1250 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, winter (heating)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	75
Width	m	5.00	Return temperature			$t_r$	°C	65
Depth	m	4.00	Room air temperature			$t_{IDA}$	°C	20
Surface area	$m^2$	20	Air inlet temperature, external air			$t_{ODA}$	°C	-12
Volume	$m^3$	60						
Distance from sound source <sup>1)</sup>	m	3.00	<sup>1)</sup> Direction factor Q=4 (sphere quadrant)					

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	External air operation			
Air volume flow		$\dot{V}$	$m^3/h$	30	60	90	120
Sound power level <sup>2)</sup>		$L_{WA}$	dB(A)	27	30	38	45
125 Hz		$L_{W125}$	dB	33	36	43	50
250 Hz		$L_{W250}$	dB	24	32	40	47
500 Hz		$L_{W500}$	dB	22	30	37	40
1000 Hz		$L_{W1000}$	dB	14	23	31	38
2000 Hz		$L_{W2000}$	dB	8	18	27	35
4000 Hz		$L_{W4000}$	dB	20	13	17	25
8000 Hz		$L_{W8000}$	dB	23	15	14	17
Sound pressure level <sup>2)</sup>		$L_P$	dB(A)	20	24	32	39
Power consumption		$p_{el}$	W	5	11	18	26
2-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	108.6	73.6	71.3	69.4
Water mass flow rate		$\dot{m}_w$	kg/h	87	117	174	230
Pressure loss, water side		$\Delta p_w$	kPa	4.1	7.2	15.2	25.5
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	201	356	481	596
Heating power total		$\dot{Q}_H$	W	1213	1723	2515	3277
Useful heating power		$\dot{Q}_{H,nutz}$	W	892	1080	1550	1991
4-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	78.4	53.2	51.1	49.4
Water mass flow rate		$\dot{m}_w$	kg/h	61	82	122	161
Pressure loss, water side		$\Delta p_w$	kPa	1.5	2.6	5.6	9.3
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	201	356	481	596
Heating power total		$\dot{Q}_H$	W	910	1313	1905	2472
Useful heating power		$\dot{Q}_{H,nutz}$	W	588	669	940	1186

<sup>2)</sup> Approximation in acc. with VDI 2081

### UZA (length 1250 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)								
Room data	Unit	Value	Climate data, winter (heating)			Symbol	Unit	Value
Height	m	3.00	Flow temperature			$t_v$	°C	55
Width	m	5.00	Return temperature			$t_r$	°C	45
Depth	m	4.00	Room air temperature			$t_{IDA}$	°C	20
Surface area	$m^2$	20	Air inlet temperature, external air			$t_{ODA}$	°C	-12
Volume	$m^3$	60						
Distance from sound source <sup>1)</sup>	m	3.00	<sup>1)</sup> Direction factor Q=4 (sphere quadrant)					

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	External air operation			
Air volume flow		$\dot{V}$	$m^3/h$	30	60	90	120
Sound power level <sup>2)</sup>		$L_{WA}$	dB(A)	27	30	38	45
125 Hz		$L_{W125}$	dB	33	36	43	50
250 Hz		$L_{W250}$	dB	24	32	40	47
500 Hz		$L_{W500}$	dB	22	30	37	40
1000 Hz		$L_{W1000}$	dB	14	23	31	38
2000 Hz		$L_{W2000}$	dB	8	18	27	35
4000 Hz		$L_{W4000}$	dB	20	13	17	25
8000 Hz		$L_{W8000}$	dB	23	15	14	17
Sound pressure level <sup>2)</sup>		$L_{PA}$	dB(A)	20	24	32	39
Power consumption		$p_{el}$	W	5	11	18	26
2-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	73.1	52.8	50.6	48.5
Water mass flow rate		$\dot{m}_w$	kg/h	56	81	121	158
Pressure loss. water side		$\Delta p_w$	kPa	1.9	3.8	7.9	13
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	201	356	481	596
Heating power total		$\dot{Q}_H$	W	856	1304	1890	2436
Useful heating power		$\dot{Q}_{H,nutz}$	W	535	661	925	1149
4-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	53.6	38.7	36.6	34.8
Water mass flow rate		$\dot{m}_w$	kg/h	39	57	85	110
Pressure loss. water side		$\Delta p_w$	kPa	0.7	1.4	2.9	4.8
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	201	356	481	596
Heating power total		$\dot{Q}_H$	W	660	1020	1467	1884
Useful heating power		$\dot{Q}_{H,nutz}$	W	338	376	502	597

### UZA (length 1250 mm) – dimensioning examples

Basic conditions: building/room type T [s] according to VDI 2081 (individual office)							
Room data	Unit	Value	Climate data, winter (heating)			Symbol	Unit
Height	m	3.00	Flow temperature			$t_v$	°C
Width	m	5.00	Return temperature			$t_r$	°C
Depth	m	4.00	Room air temperature			$t_{IDA}$	°C
Surface area	$m^2$	20	Air inlet temperature, external air			$t_{ODA}$	°C
Volume	$m^3$	60					
Distance from sound source <sup>1)</sup>	m	3.00	<sup>1)</sup> Direction factor Q=4 (sphere quadrant)				

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	External air operation			
Air volume flow		$\dot{V}$	$m^3/h$	30	60	90	120
Sound power level <sup>2)</sup>		$L_{WA}$	dB(A)	27	30	38	45
125 Hz		$L_{W125}$	dB	33	36	43	50
250 Hz		$L_{W250}$	dB	24	32	40	47
500 Hz		$L_{W500}$	dB	22	30	37	40
1000 Hz		$L_{W1000}$	dB	14	23	31	38
2000 Hz		$L_{W2000}$	dB	8	18	27	35
4000 Hz		$L_{W4000}$	dB	20	13	17	25
8000 Hz		$L_{W8000}$	dB	23	15	14	17
Sound pressure level <sup>2)</sup>		$L_{PA}$	dB(A)	24	24	32	39
Power consumption		$p_{el}$	W	5	11	18	26
2-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	60.4	45	42.8	40.7
Water mass flow rate		$\dot{m}_w$	kg/h	90	136	201	262
Pressure loss, water side		$\Delta p_w$	kPa	4.6	9.9	20.7	33.9
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	201	356	481	596
<b>Heating power total</b>		$\dot{Q}_H$	<b>W</b>	<b>728</b>	<b>1146</b>	<b>1655</b>	<b>2122</b>
<b>Useful heating power</b>		$\dot{Q}_{H, nutz}$	<b>W</b>	<b>407</b>	<b>503</b>	<b>690</b>	<b>835</b>
4-pipe system		Symbol	Unit	External air operation			
Supply air temperature		$t_{SUP}$	°C	44.7	33.2	31.2	29.4
Water mass flow rate		$\dot{m}_w$	kg/h	63	95	141	183
Pressure loss, water side		$\Delta p_w$	kPa	1.7	3.6	7.6	12.4
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	201	356	481	596
<b>Heating power total</b>		$\dot{Q}_H$	<b>W</b>	<b>570</b>	<b>909</b>	<b>1303</b>	<b>1664</b>
<b>Useful heating power</b>		$\dot{Q}_{H, nutz}$	<b>W</b>	<b>249</b>	<b>265</b>	<b>337</b>	<b>377</b>

<sup>2)</sup> Approximation in acc. with VDI 2081





**Model UZAS - ventilation unit for floor installation. Decentralised ventilation unit for floor installation, for heating, cooling and forced convection ventilation with heat recovery.**

#### Description

The UZAS is a ventilation unit for floor installation that offers the following functions:

- Supply air (SUP)
- Exhaust air (ETA)
- Secondary air (SEC)
- Heat recovery
- Heating
- Cooling

The highly compact design of the UZAS allows it to be integrated into the building structure with ease. A grid width of 345 mm in the visible area makes the unit the ideal choice even in buildings with high architectural demands. Thanks to the cover grid, simple maintenance tasks such as filter replacement can be performed without any problems.

For more extensive maintenance work, all components can be accessed with ease via an inspection cover in the floor area.

Special insulation material conforming to VDI 6022 creates optimum thermal and sound insulation.

The heat recovery unit reduces the amount of additional energy required for room temperature control to the absolute minimum.

If you are working with the heat recovery unit and there is a large difference in temperature between the external air and the air in the room, a stainless steel condensate trough is used to catch any condensate.

If required, this can then be discharged via a condensate drain.

An integrated heat exchanger (2- or 4-pipe system) conditions the room air and supplies air to the room whilst taking acoustic and comfort requirements into consideration. The external and exhaust air volume flow of up to 120 m<sup>3</sup>/h (supply and exhaust air) is achieved by means of two EC radial fans that are linked from a control perspective. Sequential activation of





### Application areas

Decentralised floor ventilation units are ideally suited to areas with high demands in terms of room air quality and thermal comfort.

- Offices and administration rooms
- Business premises
- Reception areas and foyers
- Exhibition rooms
- Rooms requiring external air
- Rooms where windows cannot be opened
- Rooms whose appearance and layout should not be disturbed by heating components

### Product benefits

- Eurokonus valve connection for time-saving valve installation
- System for heating, cooling and ventilation
- High calorific output with low acoustic load
- Pleasant room climate thanks to air supply in the vicinity of the facade
- Load-bearing
- For use in false floors
- Can be adapted to suit the specific requirements of the building
- Infinitely adjustable control
- Low installation depth

### Method of operation


The outdoor air (ODA) is drawn in directly via the facade and passes through a filter element (F7).

The supply air opening is closed automatically by a return spring motor when the unit is switched off (normally closed). There is a heat recovery unit located downstream of the supply air fan units, which is responsible for energy exchange between the supply and exhaust air (heat recovery ratio of up to 60%). Air whose temperature is precontrolled using this equipment is heated or cooled by a heat exchanger, according to the room temperature that is required. The conditioned supply air (SUP) is supplied to the room via the cover grating located in the visible area of the unit.

The exhaust air (ETA) is removed from the room via the cover and purified by a coarse dust filter. Once the exhaust air has passed through the heat recovery unit, it is conveyed outdoors as outgoing air (EHA) via an exhaust air opening (with flap). The exhaust air flap performs the same functions as the supply air flap.

Additionally, depending on the required heating or cooling power, room air is drawn in by means of the integrated secondary air fan, brought to the appropriate temperature in the heat exchanger, and fed back into the room as secondary air (SEC). This significantly increases the useful power available to the room.

## UZAS – dimensions



No.	Dimension	Value	Unit
1	Length of housing (visible area)	1000	mm
2	Width of entire unit	824	mm
3	Width of function unit under FFB (invisible area)	478	mm
4	Length of function unit under FFB	801	mm
5	Distance between housing and supply air opening	160	mm
6	Width of supply air opening	240	mm
7	Distance between supply air and outgoing air opening	154	mm
8	Width of outgoing air opening	250	mm
9	Distance between housing and outgoing air opening	196	mm
10	Distance from top to supply air opening/outgoing air opening	119	mm
11	Height of supply air opening/outgoing air opening	50	mm
12	Height of function unit under FFB (invisible area)	172	mm
13	Height of housing (visible area)	214	mm
14	Width of housing (visible area)	345	mm

Dimensions and position of the supply and external air connections can be individually adapted.



*Project: Individual office in Hafenklang complex, Hamburg (Germany)*

#### **Available as an option:**

##### **Preinstalled water connection**

Water connections preinstalled at the factory are available as accessories for emcotherm floor convectors. The connection set consists of:

1. Thermostat valve  
Standard TVU-E or TVU-D  
(optional: TVU-V-E or TVU-V-D)
2. Continuous actuator  
emcoMFC-Z-MS-S
3. Shutoff return screw connection
4. Connections inside tray, fully piped and leading outward (connection  $\frac{3}{4}$ " AG); testing for leaks

#### **Benefits:**

- Huge time savings during installation
- Dirt cannot get into the floor tray during installation as the tray is able to remain sealed
- The media and electrical connections are supplied outside of the floor tray
- Media connections are fully tested for leaks at the factory

#### **Available as an option:**

##### **Ready-to-use electrical version**

All electrical components are pre-wired at the factory and attached to the exterior of the tray by means of screw-in connectors. The customer can carry out wiring work outside the tray easily using the mating connectors supplied.

## UZAS (width 345 mm, length 1000 mm) – dimensioning examples

### Basic conditions: building/room type T [s] according to VDI 2081 (individual office)

Room data	Unit	Value	Climate data, summer (cooling)	Symbol	Unit	Value
Height	m	3.00	Flow temperature	$t_v$	°C	6
Width	m	5.00	Return temperature	$t_r$	°C	12
Depth	m	4.00	Air inlet temperature, secondary air	$t_{sec}$	°C	26
Surface area	$m^2$	20	Relative humidity, secondary air	$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air	$t_{oda}$	°C	32
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air	$\varphi_{oda}$	%	40

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system	Symbol	Unit	Secondary air operation								
External air component	$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	30	30	30
Secondary air component	$\dot{V}_{sec}$	$m^3/h$	32	67	104	147	187	32	67	104	147
Supply air quantity	$\dot{V}_{sup}$	$m^3/h$	32	67	104	147	187	62	97	134	177
Total sound power level	$L_{wa}$	dB(A)	22	25	33	41	48	28	29	34	41
Octave band sound power 125 Hz	$L_{wa125}$	dB	30	33	37	40	43	34	36	38	41
Octave band sound power 250 Hz	$L_{wa250}$	dB	12	23	32	39	45	22	26	32	39
Octave band sound power 500 Hz	$L_{wa500}$	dB	8	22	32	41	48	17	24	32	41
Octave band sound power 1000 Hz	$L_{wa1000}$	dB	3	16	27	36	44	7	17	27	36
Octave band sound power 2000 Hz	$L_{wa2000}$	dB	3	12	21	29	36	3	13	21	29
Octave band sound power 4000 Hz	$L_{wa4000}$	dB	8	13	17	22	25	10	14	18	22
Octave band sound power 8000 Hz	$L_{wa8000}$	dB	22	21	21	22	24	28	27	27	27
Sound pressure level <sup>2)</sup>	$L_{pa}$	dB(A)	16	19	27	35	42	21	23	28	35
Power consumption	$p_{el}$	W	2	3	6	11	17	6	7	10	15
2-pipe system	Symbol	Unit	Secondary air operation								
Supply air temperature	$t_{sup}$	°C	13	13	13	13	14	13	13	13	14
Condensate quantity	$\dot{m}_k$	l/h	0.1	0.2	0.3	0.4	0.4	0.2	0.3	0.4	0.5
Water mass flow rate	$\dot{m}_w$	l/h	28	61	92	124	147	64	94	121	148
Water-side pressure loss	$\Delta p_w$	kPa	0.0	0.4	0.9	1.5	2.0	0.4	0.9	1.4	2.0
Heat recovery	$\dot{Q}_{WRG}$	W	0	0	0	0	0	33	33	33	33
Cooling power, water side	$\dot{Q}_{k,water}$	W	194	429	647	866	1031	446	657	849	1036
Cooling power, latent	$\dot{Q}_{k,lat}$	W	57	134	198	252	279	151	214	263	299
<b>Cooling power, total</b>	$\dot{Q}_k$	<b>W</b>	<b>194</b>	<b>429</b>	<b>647</b>	<b>866</b>	<b>1031</b>	<b>479</b>	<b>690</b>	<b>882</b>	<b>1070</b>
<b>Useful cooling power</b>	$\dot{Q}_{k,nutz}$	<b>W</b>	<b>136</b>	<b>295</b>	<b>449</b>	<b>614</b>	<b>751</b>	<b>270</b>	<b>418</b>	<b>560</b>	<b>713</b>
4-pipe system	Symbol	Unit	Secondary air operation								
Supply air temperature	$t_{sup}$	°C	13.8	13.4	13.5	14.0	14.4	13.6	13.7	14.0	14.4
Condensate quantity	$\dot{m}_k$	l/h	0.1	0.2	0.3	0.3	0.4	0.2	0.3	0.3	0.4
Water mass flow rate	$\dot{m}_w$	l/h	25	56	84	112	133	58	86	110	134
Pressure loss, water side	$\Delta p_w$	kPa	0.0	0.3	0.6	1.1	1.4	0.3	0.6	1.0	1.4
Heat recovery (WRG)	$\dot{Q}_{WRG}$	W	0	0	0	0	0	33	33	33	33
Cooling power, water side	$\dot{Q}_{k,water}$	W	176	391	588	785	930	407	599	771	937
Cooling power, latent	$\dot{Q}_{k,lat}$	W	47	112	164	204	220	129	181	218	240
<b>Cooling power, total</b>	$\dot{Q}_k$	<b>W</b>	<b>176</b>	<b>391</b>	<b>588</b>	<b>785</b>	<b>930</b>	<b>441</b>	<b>632</b>	<b>804</b>	<b>971</b>
<b>Useful cooling power</b>	$\dot{Q}_{k,nutz}$	<b>W</b>	<b>129</b>	<b>278</b>	<b>424</b>	<b>580</b>	<b>710</b>	<b>253</b>	<b>393</b>	<b>528</b>	<b>672</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																
30	60	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
187	32	67	104	147	187	32	67	104	147	187	31	64	99	140	178	
217	92	127	164	207	247	122	157	194	237	277	151	184	219	260	298	
48	31	32	35	42	48	36	36	38	42	48	42	42	42	44	49	
44	40	41	42	43	45	45	45	46	46	47	50	50	50	51	51	
45	34	35	36	40	45	40	40	41	43	46	46	46	46	47	49	
48	29	29	34	41	48	34	34	36	42	48	39	39	40	43	48	
44	22	22	28	36	44	28	28	30	37	44	33	34	34	38	44	
36	17	18	22	29	36	21	21	24	30	36	25	25	26	31	36	
25	16	17	20	23	26	17	17	20	23	26	18	19	21	23	26	
28	22	23	24	25	26	20	21	23	24	25	21	22	23	24	25	
42	25	26	29	35	42	30	30	32	36	42	36	36	38	43		
21	12	13	16	21	27	19	20	23	28	34	27	28	31	36	42	
Mixed air operation. 2-pipe system																
14	13	13	14	14	15	13	14	14	15	15	14	14	15	15	16	
0.5	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.6	0.6	0.6	0.6	0.5	
167	97	123	147	169	184	128	151	170	187	198	155	173	188	201	207	
2.5	1.0	1.5	2.0	2.6	3.0	1.6	2.1	2.6	3.1	3.4	2.2	2.7	3.1	3.5	3.7	
33	67	67	67	67	67	90	90	90	90	90	112	112	112	112	112	
1171	677	863	1028	1183	1286	895	1054	1190	1311	1383	1084	1211	1316	1404	1448	
308	234	282	315	331	322	303	336	353	348	319	358	375	376	355	313	
<b>1204</b>	<b>744</b>	<b>930</b>	<b>1094</b>	<b>1249</b>	<b>1353</b>	<b>985</b>	<b>1144</b>	<b>1281</b>	<b>1402</b>	<b>1473</b>	<b>1195</b>	<b>1322</b>	<b>1428</b>	<b>1515</b>	<b>1560</b>	
<b>838</b>	<b>394</b>	<b>531</b>	<b>663</b>	<b>802</b>	<b>915</b>	<b>508</b>	<b>634</b>	<b>754</b>	<b>880</b>	<b>980</b>	<b>606</b>	<b>716</b>	<b>820</b>	<b>929</b>	<b>1015</b>	
Mixed air operation. 4-pipe system																
14.9	13.8	14.0	14.4	14.9	15.4	14.2	14.5	14.9	15.4	15.9	14.6	14.9	15.3	15.8	16.3	
0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.4	0.4	0.5	0.5	0.5	0.5	0.4	
150	88	112	133	152	165	117	137	154	168	176	141	157	170	180	184	
1.8	0.7	1.1	1.4	1.8	2.1	1.1	1.5	1.8	2.2	2.3	1.6	1.9	2.2	2.4	2.5	
33	67	67	67	67	67	90	90	90	90	90	112	112	112	112	112	
1053	619	786	932	1067	1153	817	958	1077	1178	1233	987	1097	1187	1257	1287	
238	200	237	259	262	242	258	280	286	268	229	301	308	299	267	215	
<b>1086</b>	<b>686</b>	<b>853</b>	<b>999</b>	<b>1133</b>	<b>1219</b>	<b>907</b>	<b>1048</b>	<b>1167</b>	<b>1268</b>	<b>1324</b>	<b>1098</b>	<b>1209</b>	<b>1299</b>	<b>1369</b>	<b>1398</b>	
<b>790</b>	<b>369</b>	<b>499</b>	<b>623</b>	<b>755</b>	<b>861</b>	<b>475</b>	<b>594</b>	<b>707</b>	<b>826</b>	<b>920</b>	<b>566</b>	<b>669</b>	<b>767</b>	<b>870</b>	<b>952</b>	

## UZAS (width 345 mm, length 1000 mm) – dimensioning examples

### Basic conditions: building/room type T [s] according to VDI 2081 (individual office)

Room data	Unit	Value	Climate data, summer (cooling)	Symbol	Unit	Value
Height	m	3.00	Flow temperature	$t_v$	°C	10
Width	m	5.00	Return temperature	$t_r$	°C	15
Depth	m	4.00	Air inlet temperature, secondary air	$t_{sec}$	°C	26
Surface area	$m^2$	20	Relative humidity, secondary air	$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air	$t_{oda}$	°C	32
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air	$\varphi_{oda}$	%	40

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	Secondary air operation								
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	30	30	30
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	32	67	104	147	187	32	67	104	147
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	32	67	104	147	187	62	97	134	177
Total sound power level		$L_{wa}$	dB(A)	22	25	33	41	48	28	29	34	41
Octave band sound power 125 Hz		$L_{wa125}$	dB	30	33	37	40	43	34	36	38	41
Octave band sound power 250 Hz		$L_{wa250}$	dB	12	23	32	39	45	22	26	32	39
Octave band sound power 500 Hz		$L_{wa500}$	dB	8	22	32	41	48	17	24	32	41
Octave band sound power 1000 Hz		$L_{wa1000}$	dB	3	16	27	36	44	7	17	27	36
Octave band sound power 2000 Hz		$L_{wa2000}$	dB	3	12	21	29	36	3	13	21	29
Octave band sound power 4000 Hz		$L_{wa4000}$	dB	8	13	17	22	25	10	14	18	22
Octave band sound power 8000 Hz		$L_{wa8000}$	dB	22	21	21	22	24	28	27	27	27
Sound pressure level <sup>2)</sup>		$L_{pa}$	dB(A)	16	19	27	35	42	21	23	28	35
Power consumption		$p_{el}$	W	2	3	6	11	17	6	7	10	15
2-pipe system		Symbol	Unit	Secondary air operation								
Supply air temperature		$t_{sup}$	°C	15.7	15.3	15.5	15.8	16.2	15.5	15.6	15.8	16.2
Condensate quantity		$\dot{m}_k$	l/h	0.0	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2
Water mass flow rate		$\dot{m}_w$	l/h	22	49	73	96	112	53	77	98	116
Water-side pressure loss		$\Delta p_w$	kPa	0.0	0.3	0.6	0.9	1.2	0.3	0.6	1.0	1.3
Heat recovery		$\dot{Q}_{WRG}$	W	0	0	0	0	0	33	33	33	33
Cooling power, water side		$\dot{Q}_{k,water}$	W	126	285	427	562	654	311	450	569	676
Cooling power, latent		$\dot{Q}_{k,lat}$	W	17	50	69	71	54	72	92	98	83
<b>Cooling power, total</b>		$\dot{Q}_k$	W	<b>126</b>	<b>285</b>	<b>427</b>	<b>562</b>	<b>654</b>	<b>345</b>	<b>483</b>	<b>602</b>	<b>709</b>
<b>Useful cooling power</b>		$\dot{Q}_{k,nutz}$	W	<b>109</b>	<b>235</b>	<b>358</b>	<b>490</b>	<b>600</b>	<b>214</b>	<b>332</b>	<b>446</b>	<b>568</b>
4-pipe system		Symbol	Unit	Secondary air operation								
Supply air temperature		$t_{sup}$	°C	16.3	15.9	16.1	16.4	16.7	16.2	16.2	16.4	16.8
Condensate quantity		$\dot{m}_k$	l/h	0.0	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1
Water mass flow rate		$\dot{m}_w$	l/h	19	43	64	84	98	48	68	86	101
Pressure loss, water side		$\Delta p_w$	kPa	0.0	0.2	0.4	0.6	0.8	0.2	0.4	0.7	0.9
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	0	0	0	0	0	33	33	33	33
Cooling power, water side		$\dot{Q}_{k,water}$	W	111	252	376	492	569	278	399	501	590
Cooling power, latent		$\dot{Q}_{k,lat}$	W	8	30	38	28	0	52	61	56	30
<b>Cooling power, total</b>		$\dot{Q}_k$	W	<b>111</b>	<b>252</b>	<b>376</b>	<b>492</b>	<b>569</b>	<b>311</b>	<b>432</b>	<b>535</b>	<b>623</b>
<b>Useful cooling power</b>		$\dot{Q}_{k,nutz}$	W	<b>103</b>	<b>222</b>	<b>338</b>	<b>463</b>	<b>569</b>	<b>201</b>	<b>312</b>	<b>420</b>	<b>535</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																
30	60	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
187	32	67	104	147	187	32	67	104	147	187	31	64	99	140	178	
217	92	127	164	207	247	122	157	194	237	277	151	184	219	260	298	
48	31	32	35	42	48	36	36	38	42	48	42	42	42	44	49	
44	40	41	42	43	45	45	45	46	46	47	50	50	50	51	51	
45	34	35	36	40	45	40	40	41	43	46	46	46	46	47	49	
48	29	29	34	41	48	34	34	36	42	48	39	39	40	43	48	
44	22	22	28	36	44	28	28	30	37	44	33	34	34	38	44	
36	17	18	22	29	36	21	21	24	30	36	25	25	26	31	36	
25	16	17	20	23	26	17	17	20	23	26	18	19	21	23	26	
28	22	23	24	25	26	20	21	23	24	25	21	22	23	24	25	
42	25	26	29	35	42	30	30	32	36	42	36	36	38	43		
21	12	13	16	21	27	19	20	23	28	34	27	28	31	36	42	
Mixed air operation. 2-pipe system																
16.6	15.7	15.9	16.2	16.6	17.0	16.0	16.3	16.6	17.0	17.4	16.3	16.6	17.0	17.4	17.8	
0.1	0.2	0.2	0.2	0.2	0.1	0.3	0.2	0.2	0.1	0.1	0.3	0.3	0.2	0.1	0.0	
127	82	102	118	132	139	109	125	137	145	148	132	143	151	155	158	
1.6	0.7	1.1	1.4	1.7	1.8	1.2	1.5	1.8	2.0	2.0	1.7	1.9	2.1	2.2	2.3	
33	67	67	67	67	67	90	90	90	90	90	112	112	112	112	112	
742	479	595	690	769	809	636	728	799	848	863	769	835	881	904	923	
49	117	123	114	82	31	150	142	117	66	0	170	149	113	49	0	
<b>775</b>	<b>546</b>	<b>662</b>	<b>757</b>	<b>836</b>	<b>875</b>	<b>726</b>	<b>818</b>	<b>889</b>	<b>938</b>	<b>953</b>	<b>880</b>	<b>947</b>	<b>993</b>	<b>1016</b>	<b>1035</b>	
<b>668</b>	<b>312</b>	<b>422</b>	<b>526</b>	<b>638</b>	<b>728</b>	<b>402</b>	<b>502</b>	<b>597</b>	<b>697</b>	<b>778</b>	<b>478</b>	<b>565</b>	<b>648</b>	<b>734</b>	<b>802</b>	
Mixed air operation. 4-pipe system																
17.1	16.4	16.5	16.8	17.2	17.5	16.7	16.9	17.2	17.6	18.0	17.0	17.3	17.6	17.9	18.3	
0.0	0.1	0.1	0.1	0.1	0.0	0.2	0.2	0.1	0.0	0.0	0.2	0.2	0.1	0.0	0.0	
113	73	90	104	115	126	97	110	120	127	140	117	126	132	138	150	
1.1	0.5	0.7	0.9	1.1	1.3	0.8	1.0	1.2	1.3	1.6	1.1	1.3	1.4	1.5	1.8	
33	67	67	67	67	67	90	90	90	90	90	112	112	112	112	112	
657	427	527	607	668	737	566	643	699	739	815	682	735	767	807	872	
0	85	82	62	19	0	107	89	55	0	0	117	87	42	0	0	
<b>690</b>	<b>494</b>	<b>594</b>	<b>674</b>	<b>735</b>	<b>804</b>	<b>656</b>	<b>733</b>	<b>789</b>	<b>829</b>	<b>905</b>	<b>794</b>	<b>846</b>	<b>879</b>	<b>919</b>	<b>984</b>	
<b>632</b>	<b>292</b>	<b>395</b>	<b>494</b>	<b>599</b>	<b>687</b>	<b>374</b>	<b>469</b>	<b>559</b>	<b>654</b>	<b>730</b>	<b>444</b>	<b>527</b>	<b>605</b>	<b>686</b>	<b>751</b>	

## UZAS (width 345 mm, length 1000 mm) – dimensioning examples

**Basic conditions: building/room type T [s] according to VDI 2081 (individual office)**

Room data	Unit	Value	Climate data, summer (cooling)					Symbol	Unit	Value
Height	m	3.00	Flow temperature					$t_v$	°C	16
Width	m	5.00	Return temperature					$t_r$	°C	18
Depth	m	4.00	Air inlet temperature, secondary air					$t_{sec}$	°C	26
Surface area	$m^2$	20	Relative humidity, secondary air					$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air					$t_{oda}$	°C	32
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air					$\varphi_{oda}$	%	40

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	Secondary air operation								
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	30	30	30
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	32	67	104	147	187	32	67	104	147
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	32	67	104	147	187	62	97	134	177
Total sound power level		$L_{wa}$	dB(A)	22	25	33	41	48	28	29	34	41
Octave band sound power 125 Hz		$L_{wa125}$	dB	30	33	37	40	43	34	36	38	41
Octave band sound power 250 Hz		$L_{wa250}$	dB	12	23	32	39	45	22	26	32	39
Octave band sound power 500 Hz		$L_{wa500}$	dB	8	22	32	41	48	17	24	32	41
Octave band sound power 1000 Hz		$L_{wa1000}$	dB	3	16	27	36	44	7	17	27	36
Octave band sound power 2000 Hz		$L_{wa2000}$	dB	3	12	21	29	36	3	13	21	29
Octave band sound power 4000 Hz		$L_{wa4000}$	dB	8	13	17	22	25	10	14	18	22
Octave band sound power 8000 Hz		$L_{wa8000}$	dB	22	21	21	22	24	28	27	27	27
Sound pressure level <sup>2)</sup>		$L_{pa}$	dB(A)	16	19	27	35	42	21	23	28	35
Power consumption		$p_{el}$	W	2	3	6	11	17	6	7	10	15
2-pipe system		Symbol	Unit	Secondary air operation								
Supply air temperature		$t_{sup}$	°C	19.1	18.8	18.9	19.1	19.4	19.0	19.0	19.2	19.4
Condensate quantity		$\dot{m}_k$	l/h	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Water mass flow rate		$\dot{m}_w$	l/h	31	68	104	142	174	72	106	139	174
Water-side pressure loss		$\Delta p_w$	kPa	0.1	0.5	1.1	1.9	2.7	0.6	1.1	1.8	2.7
Heat recovery		$\dot{Q}_{WRG}$	W	0	0	0	0	0	33	33	33	33
Cooling power, water side		$\dot{Q}_{K,water}$	W	73	159	242	331	406	168	248	324	407
Cooling power, latent		$\dot{Q}_{K,lat}$	W	0	0	0	0	0	0	0	0	0
<b>Cooling power, total</b>		$\dot{Q}_k$	<b>W</b>	<b>73</b>	<b>159</b>	<b>242</b>	<b>331</b>	<b>406</b>	<b>201</b>	<b>281</b>	<b>358</b>	<b>440</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>73</b>	<b>159</b>	<b>242</b>	<b>331</b>	<b>406</b>	<b>142</b>	<b>222</b>	<b>299</b>	<b>382</b>
4-pipe system		Symbol	Unit	Secondary air operation								
Supply air temperature		$t_{sup}$	°C	19.5	19.2	19.3	19.5	19.8	19.5	19.5	19.6	19.8
Condensate quantity		$\dot{m}_k$	l/h	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Water mass flow rate		$\dot{m}_w$	l/h	30	64	98	134	164	68	100	131	165
Pressure loss, water side		$\Delta p_w$	kPa	0.0	0.4	0.8	1.4	2.1	0.4	0.9	1.4	2.1
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	0	0	0	0	0	33	33	33	33
Cooling power, water side		$\dot{Q}_{K,water}$	W	69	150	228	313	383	158	234	306	384
Cooling power, latent		$\dot{Q}_{K,lat}$	W	0	0	0	0	0	0	0	0	0
<b>Cooling power, total</b>		$\dot{Q}_k$	<b>W</b>	<b>69</b>	<b>150</b>	<b>228</b>	<b>313</b>	<b>383</b>	<b>192</b>	<b>267</b>	<b>340</b>	<b>418</b>
<b>Useful cooling power</b>		$\dot{Q}_{K,nutz}$	<b>W</b>	<b>69</b>	<b>150</b>	<b>228</b>	<b>313</b>	<b>383</b>	<b>133</b>	<b>208</b>	<b>281</b>	<b>359</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																
30	60	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
187	32	67	104	147	187	32	67	104	147	187	31	64	99	140	178	
217	92	127	164	207	247	122	157	194	237	277	151	184	219	260	298	
48	31	32	35	42	48	36	36	38	42	48	42	42	42	44	49	
44	40	41	42	43	45	45	45	46	46	47	50	50	50	51	51	
45	34	35	36	40	45	40	40	41	43	46	46	46	46	47	49	
48	29	29	34	41	48	34	34	36	42	48	39	39	40	43	48	
44	22	22	28	36	44	28	28	30	37	44	33	34	34	38	44	
36	17	18	22	29	36	21	21	24	30	36	25	25	26	31	36	
25	16	17	20	23	26	17	17	20	23	26	18	19	21	23	26	
28	22	23	24	25	26	20	21	23	24	25	21	22	23	24	25	
42	25	26	29	35	42	30	30	32	36	42	36	36	38	43		
21	12	13	16	21	27	19	20	23	28	34	27	28	31	36	42	
Mixed air operation. 2-pipe system																
19.7	19.2	19.3	19.5	19.7	20.0	19.4	19.6	19.8	20.1	20.3	19.7	19.9	20.1	20.3	20.6	
0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
203	110	142	172	204	230	149	178	206	235	258	185	210	234	259	278	
3.6	1.2	1.9	2.7	3.6	4.5	2.1	2.9	3.7	4.7	5.5	3.1	3.8	4.7	5.6	6.4	
33	67	67	67	67	67	90	90	90	90	90	112	112	112	112	112	
474	257	331	402	477	537	349	416	480	547	601	432	491	546	604	649	
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
<b>508</b>	<b>324</b>	<b>398</b>	<b>468</b>	<b>543</b>	<b>604</b>	<b>439</b>	<b>506</b>	<b>570</b>	<b>637</b>	<b>691</b>	<b>544</b>	<b>602</b>	<b>657</b>	<b>715</b>	<b>761</b>	
<b>449</b>	<b>207</b>	<b>280</b>	<b>351</b>	<b>426</b>	<b>487</b>	<b>263</b>	<b>330</b>	<b>395</b>	<b>462</b>	<b>515</b>	<b>310</b>	<b>368</b>	<b>424</b>	<b>481</b>	<b>527</b>	
Mixed air operation. 4-pipe system																
20.1	19.7	19.7	19.9	20.1	20.4	19.9	20.0	20.2	20.5	20.7	20.2	20.3	20.5	20.7	21.0	
0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
192	104	134	163	193	218	141	168	194	221	243	175	199	221	244	263	
2.7	0.9	1.4	2.0	2.8	3.4	1.6	2.2	2.8	3.5	4.2	2.3	2.9	3.5	4.2	4.8	
33	67	67	67	67	67	90	90	90	90	90	112	112	112	112	112	
448	243	313	379	450	508	329	393	453	517	567	408	463	515	570	613	
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
<b>481</b>	<b>310</b>	<b>379</b>	<b>446</b>	<b>517</b>	<b>574</b>	<b>419</b>	<b>483</b>	<b>544</b>	<b>607</b>	<b>658</b>	<b>520</b>	<b>575</b>	<b>627</b>	<b>682</b>	<b>725</b>	
<b>423</b>	<b>192</b>	<b>262</b>	<b>329</b>	<b>399</b>	<b>457</b>	<b>243</b>	<b>307</b>	<b>368</b>	<b>431</b>	<b>482</b>	<b>286</b>	<b>341</b>	<b>393</b>	<b>448</b>	<b>491</b>	

### UZAS (width 345 mm, length 1000 mm) – dimensioning examples

**Basic conditions: building/room type T [s] according to VDI 2081 (individual office)**

Room data	Unit	Value	Climate data, winter (heating)	Symbol	Unit	Value
Height	m	3.00	Flow temperature	$t_v$	°C	75
Width	m	5.00	Return temperature	$t_r$	°C	65
Depth	m	4.00	Air inlet temperature, secondary air	$t_{sec}$	°C	20
Surface area	$m^2$	20	Relative humidity, secondary air	$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air	$t_{oda}$	°C	-12
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air	$\varphi_{oda}$	%	50

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system	Symbol	Unit	Secondary air operation								
External air component	$\dot{V}_{oda}$	$m^3/h$	0 0 0 0 0		30 30 30 30		30 30 30 30		30 30 30 30		
Secondary air component	$\dot{V}_{sec}$	$m^3/h$	32 67 104 147 187		32 67 104 147		62 97 134 177		62 97 134 177		
Supply air quantity	$\dot{V}_{sup}$	$m^3/h$	32 67 104 147 187		28 29 34 41		28 29 34 41		28 29 34 41		
Total sound power level	$L_{wa}$	dB(A)	22 25 33 41 48		21 23 28 35		21 23 28 35		21 23 28 35		
Sound pressure level <sup>2)</sup>	$L_{pa}$	dB(A)	16 19 27 35 42		6 7 10 15		6 7 10 15		6 7 10 15		
2-pipe system	Symbol	Unit	Secondary air operation								
Supply air temperature	$t_{sup}$	°C	59.6 58.9 58.1 57.1 56.2		59.0 58.3 57.4 56.4		59.0 58.3 57.4 56.4		59.0 58.3 57.4 56.4		
Water mass flow rate	$\dot{m}_w$	l/h	37 75 114 157 195		80 117 154 195		80 117 154 195		80 117 154 195		
Water-side pressure loss	$\Delta p_w$	kPa	0.1 0.6 1.3 2.3 3.3		0.7 1.3 2.2 3.4		0.7 1.3 2.2 3.4		0.7 1.3 2.2 3.4		
Heat recovery	$\dot{Q}_{WRG}$	W	0 0 0 0 0		200 200 200 200		200 200 200 200		200 200 200 200		
Heating power, water side	$\dot{Q}_{H,water}$	W	429 877 1326 1832 2271		935 1366 1797 2280		935 1366 1797 2280		935 1366 1797 2280		
<b>Heating power, total</b>	<b><math>\dot{Q}_H</math></b>	<b>W</b>	<b>429 877 1326 1832 2271</b>		<b>1135 1566 1997 2480</b>		<b>1135 1566 1997 2480</b>		<b>1135 1566 1997 2480</b>		
<b>Useful heating power</b>	<b><math>\dot{Q}_{H,nutz}</math></b>	<b>W</b>	<b>429 877 1326 1832 2271</b>		<b>815 1246 1677 2160</b>		<b>815 1246 1677 2160</b>		<b>815 1246 1677 2160</b>		
4-pipe system	Symbol	Unit	Secondary air operation								
Supply air temperature	$t_{sup}$	°C	61.7 51.1 47.2 44.6 42.9		50.9 46.8 44.5 42.5		50.9 46.8 44.5 42.5		50.9 46.8 44.5 42.5		
Water mass flow rate	$\dot{m}_w$	l/h	39 60 81 104 123		66 85 104 125		66 85 104 125		66 85 104 125		
Pressure loss, water side	$\Delta p_w$	kPa	0.1 0.3 0.6 0.9 1.2		0.4 0.6 0.9 1.3		0.4 0.6 0.9 1.3		0.4 0.6 0.9 1.3		
Heat recovery (WRG)	$\dot{Q}_{WRG}$	W	0 0 0 0 0		200 200 200 200		200 200 200 200		200 200 200 200		
Heating power, water side	$\dot{Q}_{H,water}$	W	452 700 946 1214 1434		765 991 1217 1459		765 991 1217 1459		765 991 1217 1459		
<b>Heating power, total</b>	<b><math>\dot{Q}_H</math></b>	<b>W</b>	<b>452 700 946 1214 1434</b>		<b>965 1191 1417 1659</b>		<b>965 1191 1417 1659</b>		<b>965 1191 1417 1659</b>		
<b>Useful heating power</b>	<b><math>\dot{Q}_{H,nutz}</math></b>	<b>W</b>	<b>452 700 946 1214 1434</b>		<b>645 871 1097 1339</b>		<b>645 871 1097 1339</b>		<b>645 871 1097 1339</b>		

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																
30	60	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
187	32	67	104	147	187	32	67	104	147	187	31	64	99	140	178	
217	92	127	164	207	247	122	157	194	237	277	151	184	219	260	298	
48	31	32	35	42	48	36	36	38	42	48	42	42	42	44	49	
42	25	26	29	35	42	30	30	32	36	42	36	36	36	38	43	
21	12	13	16	21	27	19	20	23	28	34	27	28	31	36	42	
Mixed air operation. 2-pipe system																
55.4	58.1	57.4	56.6	55.5	54.6	56.7	56.1	55.4	54.4	53.5	55.4	54.9	54.2	53.4	52.5	
231	122	157	193	232	266	165	199	233	270	302	206	237	267	301	330	
4.6	1.4	2.3	3.3	4.6	5.9	2.5	3.5	4.6	6.1	7.4	3.7	4.8	5.9	7.4	8.8	
200	400	400	400	400	400	542	542	542	542	542	671	671	671	671	671	
2698	1418	1833	2246	2706	3103	1923	2321	2715	3152	3526	2398	2760	3118	3515	3854	
2898	1818	2234	2646	3107	3503	2464	2863	3257	3694	4068	3068	3431	3789	4186	4525	
2578	1178	1594	2006	2467	2863	1504	1903	2297	2734	3108	1788	2151	2509	2906	3245	
Mixed air operation. 4-pipe system																
41.0	46.0	43.8	42.3	40.7	39.3	42.2	41.0	39.9	38.5	37.3	39.5	38.7	37.8	36.7	35.5	
141	89	108	125	144	158	114	131	147	162	173	137	151	164	177	185	
1.6	0.7	1.0	1.3	1.6	1.9	1.1	1.4	1.7	2.0	2.3	1.5	1.8	2.1	2.4	2.6	
200	400	400	400	400	400	542	542	542	542	542	671	671	671	671	671	
1650	1043	1256	1462	1676	1839	1330	1526	1710	1893	2022	1593	1762	1915	2062	2158	
1851	1443	1656	1863	2077	2239	1872	2068	2252	2435	2564	2264	2432	2586	2732	2829	
1531	803	1016	1223	1437	1599	912	1108	1292	1475	1604	984	1152	1306	1452	1549	

### UZAS (width 345 mm, length 1000 mm) – dimensioning examples

**Basic conditions: building/room type T [s] according to VDI 2081 (individual office)**

Room data	Unit	Value	Climate data, winter (heating)	Symbol	Unit	Value
Height	m	3.00	Flow temperature	$t_v$	°C	55
Width	m	5.00	Return temperature	$t_r$	°C	45
Depth	m	4.00	Air inlet temperature, secondary air	$t_{sec}$	°C	20
Surface area	$m^2$	20	Relative humidity, secondary air	$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air	$t_{oda}$	°C	-12
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air	$\varphi_{oda}$	%	50

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system		Symbol	Unit	Secondary air operation								
External air component		$\dot{V}_{oda}$	$m^3/h$	0	0	0	0	0	30	30	30	30
Secondary air component		$\dot{V}_{sec}$	$m^3/h$	32	67	104	147	187	32	67	104	147
Supply air quantity		$\dot{V}_{sup}$	$m^3/h$	32	67	104	147	187	62	97	134	177
Total sound power level		$L_{wa}$	dB(A)	22	25	33	41	48	28	29	34	41
Sound pressure level <sup>2)</sup>		$L_{pa}$	dB(A)	16	19	27	35	42	21	23	28	35
Power consumption		$p_{el}$	W	2	3	6	11	17	6	7	10	15
2-pipe system		Symbol	Unit	Secondary air operation								
Supply air temperature		$t_{sup}$	°C	43.8	43.4	42.9	42.3	41.7	43.4	43.0	42.4	41.8
Water mass flow rate		$\dot{m}_w$	l/h	22	45	68	94	117	52	74	96	121
Water-side pressure loss		$\Delta p_w$	kPa	0.0	0.2	0.5	0.9	1.3	0.3	0.6	1.0	1.4
Heat recovery		$\dot{Q}_{WRG}$	W	0	0	0	0	0	200	200	200	200
Heating power, water side		$\dot{Q}_{H,water}$	W	258	527	796	1099	1362	609	868	1126	1414
<b>Heating power, total</b>		$\dot{Q}_h$	<b>W</b>	<b>258</b>	<b>527</b>	<b>796</b>	<b>1099</b>	<b>1362</b>	<b>809</b>	<b>1068</b>	<b>1326</b>	<b>1614</b>
<b>Useful heating power</b>		$\dot{Q}_{H,nutz}$	<b>W</b>	<b>258</b>	<b>527</b>	<b>796</b>	<b>1099</b>	<b>1362</b>	<b>489</b>	<b>748</b>	<b>1006</b>	<b>1294</b>
4-pipe system		Symbol	Unit	Secondary air operation								
Supply air temperature		$t_{sup}$	°C	45.0	38.6	36.2	34.6	33.5	38.0	35.5	34.1	33.0
Water mass flow rate		$\dot{m}_w$	l/h	23	36	48	62	72	43	54	65	76
Pressure loss, water side		$\Delta p_w$	kPa	0.0	0.1	0.2	0.3	0.5	0.2	0.3	0.4	0.5
Heat recovery (WRG)		$\dot{Q}_{WRG}$	W	0	0	0	0	0	200	200	200	200
Heating power, water side		$\dot{Q}_{H,water}$	W	271	418	562	718	844	496	625	753	890
<b>Heating power, total</b>		$\dot{Q}_h$	<b>W</b>	<b>271</b>	<b>418</b>	<b>562</b>	<b>718</b>	<b>844</b>	<b>696</b>	<b>825</b>	<b>953</b>	<b>1090</b>
<b>Useful heating power</b>		$\dot{Q}_{H,nutz}$	<b>W</b>	<b>271</b>	<b>418</b>	<b>562</b>	<b>718</b>	<b>844</b>	<b>376</b>	<b>505</b>	<b>633</b>	<b>770</b>

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																
30	60	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
187	32	67	104	147	187	32	67	104	147	187	31	64	99	140	178	
217	92	127	164	207	247	122	157	194	237	277	151	184	219	260	298	
48	31	32	35	42	48	36	36	38	42	48	42	42	42	44	49	
42	25	26	29	35	42	30	30	32	36	42	36	36	36	38	43	
21	12	13	16	21	27	19	20	23	28	34	27	28	31	36	42	
Mixed air operation. 2-pipe system																
41.2	42.7	42.3	41.8	41.2	40.6	41.6	41.3	40.9	40.3	39.8	40.6	40.4	40.0	39.5	39.0	
142	81	102	123	147	167	112	132	152	174	193	141	160	178	198	215	
1.9	0.7	1.1	1.5	2.0	2.5	1.2	1.7	2.2	2.7	3.3	1.9	2.3	2.8	3.4	4.0	
200	400	400	400	400	400	542	542	542	542	542	671	671	671	671	671	
1662	943	1192	1438	1712	1946	1305	1543	1776	2034	2254	1648	1864	2076	2309	2507	
1862	1344	1593	1839	2112	2347	1846	2084	2318	2576	2796	2319	2535	2747	2980	3178	
1542	704	953	1199	1472	1707	886	1124	1358	1616	1836	1039	1255	1467	1700	1898	
Mixed air operation. 4-pipe system																
32.1	34.5	33.3	32.5	31.6	30.7	31.6	31.1	30.5	29.8	29.1	29.4	29.2	28.8	28.3	27.6	
85	59	69	79	89	97	77	86	94	103	108	93	101	107	114	118	
0.6	0.3	0.4	0.6	0.7	0.8	0.5	0.7	0.8	0.9	1.0	0.8	0.9	1.0	1.1	1.1	
200	400	400	400	400	400	542	542	542	542	542	671	671	671	671	671	
997	689	808	923	1042	1130	894	1002	1102	1199	1265	1083	1174	1254	1328	1373	
1197	1089	1209	1324	1442	1530	1436	1544	1644	1741	1806	1754	1844	1925	1999	2043	
877	449	569	684	802	890	476	584	684	781	846	474	564	645	719	763	

### UZAS (width 345 mm, length 1000 mm) – dimensioning examples

#### Basic conditions: building/room type T [s] according to VDI 2081 (individual office)

Room data	Unit	Value	Climate data, winter (heating)	Symbol	Unit	Value
Height	m	3.00	Flow temperature	$t_v$	°C	45
Width	m	5.00	Return temperature	$t_r$	°C	40
Depth	m	4.00	Air inlet temperature, secondary air	$t_{sec}$	°C	20
Surface area	$m^2$	20	Relative humidity, secondary air	$\varphi_{sec}$	%	50
Volume	$m^3$	60	Air inlet temperature, external air	$t_{oda}$	°C	-12
Distance from sound source <sup>1)</sup>	m	3.00	Relative humidity, external air	$\varphi_{oda}$	%	50

<sup>1)</sup> Direction factor Q=4 (sphere quadrant)

The following values can be derived on the basis of the specified building and climate parameters:

2- and 4-pipe system	Symbol	Unit	Secondary air operation								
External air component	$\dot{V}_{oda}$	$m^3/h$	0 0 0 0 0		30 30 30 30		30 30 30 30		30 30 30 30		
Secondary air component	$\dot{V}_{sec}$	$m^3/h$	32 67 104 147 187		32 67 104 147		62 97 134 177		62 97 134 177		
Supply air quantity	$\dot{V}_{sup}$	$m^3/h$	32 67 104 147 187		28 29 34 41		28 29 34 41		28 29 34 41		
Total sound power level	$L_{wa}$	dB(A)	22 25 33 41 48		21 23 28 35		21 23 28 35		21 23 28 35		
Sound pressure level <sup>2)</sup>	$L_{pa}$	dB(A)	16 19 27 35 42		6 7 10 15		6 7 10 15		6 7 10 15		
2-pipe system	Symbol	Unit	Secondary air operation								
Supply air temperature	$t_{sup}$	°C	37.9 37.6 37.2 36.7 36.3		37.6 37.2 36.8 36.3		37.6 37.2 36.8 36.3		37.6 37.2 36.8 36.3		
Water mass flow rate	$\dot{m}_w$	l/h	33 68 102 141 175		83 117 150 187		83 117 150 187		83 117 150 187		
Water-side pressure loss	$\Delta p_w$	kPa	0.1 0.5 1.1 1.9 2.8		0.7 1.3 2.1 3.1		0.7 1.3 2.1 3.1		0.7 1.3 2.1 3.1		
Heat recovery	$\dot{Q}_{WRG}$	W	0 0 0 0 0		200 200 200 200		200 200 200 200		200 200 200 200		
Heating power, water side	$\dot{Q}_{H,water}$	W	194 395 597 824 1021		487 681 874 1089		487 681 874 1089		487 681 874 1089		
<b>Heating power, total</b>	<b><math>\dot{Q}_H</math></b>	<b>W</b>	<b>194 395 597 824 1021</b>		<b>687 881 1074 1289</b>		<b>687 881 1074 1289</b>		<b>687 881 1074 1289</b>		
<b>Useful heating power</b>	<b><math>\dot{Q}_{H,nutz}</math></b>	<b>W</b>	<b>194 395 597 824 1021</b>		<b>367 561 754 969</b>		<b>367 561 754 969</b>		<b>367 561 754 969</b>		
4-pipe system	Symbol	Unit	Secondary air operation								
Supply air temperature	$t_{sup}$	°C	38.8 33.9 32.1 30.8 30.0		33.2 31.3 30.3 29.4		33.2 31.3 30.3 29.4		33.2 31.3 30.3 29.4		
Water mass flow rate	$\dot{m}_w$	l/h	35 54 72 92 107		68 84 100 116		68 84 100 116		68 84 100 116		
Pressure loss, water side	$\Delta p_w$	kPa	0.1 0.3 0.5 0.7 1.0		0.4 0.6 0.9 1.1		0.4 0.6 0.9 1.1		0.4 0.6 0.9 1.1		
Heat recovery (WRG)	$\dot{Q}_{WRG}$	W	0 0 0 0 0		200 200 200 200		200 200 200 200		200 200 200 200		
Heating power, water side	$\dot{Q}_{H,water}$	W	203 312 419 534 626		396 488 581 679		396 488 581 679		396 488 581 679		
<b>Heating power, total</b>	<b><math>\dot{Q}_H</math></b>	<b>W</b>	<b>203 312 419 534 626</b>		<b>596 688 781 879</b>		<b>596 688 781 879</b>		<b>596 688 781 879</b>		
<b>Useful heating power</b>	<b><math>\dot{Q}_{H,nutz}</math></b>	<b>W</b>	<b>203 312 419 534 626</b>		<b>276 368 461 559</b>		<b>276 368 461 559</b>		<b>276 368 461 559</b>		

<sup>2)</sup> Approximation in acc. with VDI 2081

Mixed air operation. 2-pipe and 4-pipe system																
30	60	60	60	60	60	90	90	90	90	90	120	120	120	120	120	120
187	32	67	104	147	187	32	67	104	147	187	31	64	99	140	178	
217	92	127	164	207	247	122	157	194	237	277	151	184	219	260	298	
48	31	32	35	42	48	36	36	38	42	48	42	42	42	44	49	
42	25	26	29	35	42	30	30	32	36	42	36	36	38	43		
21	12	13	16	21	27	19	20	23	28	34	27	28	31	36	42	
Mixed air operation. 2-pipe system																
35.9	37.0	36.7	36.3	35.8	35.4	36.0	35.8	35.5	35.1	34.6	35.0	34.9	34.7	34.3	34.0	
218	131	163	195	230	259	184	214	244	277	305	234	262	289	318	343	
4.1	1.7	2.4	3.3	4.5	5.6	3.0	4.0	5.0	6.3	7.5	4.7	5.7	6.8	8.2	9.4	
200	400	400	400	400	400	542	542	542	542	542	671	671	671	671	671	
1274	765	952	1136	1339	1513	1073	1251	1425	1616	1778	1367	1528	1685	1857	2002	
1474	1166	1352	1536	1740	1914	1614	1793	1967	2158	2320	2038	2199	2356	2528	2673	
1154	526	712	896	1100	1274	654	833	1007	1198	1360	758	919	1076	1248	1393	
Mixed air operation. 4-pipe system																
28.7	30.2	29.4	28.8	28.2	27.6	27.7	27.4	27.1	26.6	26.1	25.6	25.6	25.5	25.1	24.8	
130	95	110	124	138	149	125	138	150	162	169	153	164	173	181	186	
1.4	0.8	1.0	1.3	1.5	1.7	1.3	1.5	1.8	2.0	2.2	1.8	2.1	2.3	2.5	2.6	
200	400	400	400	400	400	542	542	542	542	542	671	671	671	671	671	
756	557	642	724	807	868	732	807	877	943	986	894	956	1010	1057	1084	
956	957	1042	1124	1208	1269	1274	1349	1418	1484	1528	1565	1626	1680	1728	1754	
636	317	402	484	568	629	314	389	458	524	568	285	346	400	448	474	



**Kampmann UK Ltd.**  
Dial House, Govett Avenue  
Shepperton, Middlesex, TW17 8AG  
Great Britain

+44 1932 228592  
[info@kampmann.co.uk](mailto:info@kampmann.co.uk)

[kampmann.co.uk](http://kampmann.co.uk)



**KAMPMANN**